

# GCC Technology

14 Patton dr  
Bloomfield, NJ 07003  
Phone: (718) 717-6579

Ticket #: 36  
Date: 2026-01-28  
Time: 03:28:27

## WORK ORDER

Customer: MSH  
158 West 124th St, New York, NY  
Phone: (917) 822-9007  
Email: paul.chowfatt@mountsinai.org

## UNITS INFORMATION

Tag	Type	Make	Model	Refrig	V	Serial
CU-ACCC-9RTU		Mitsubishi	PURY-EP240TNU-A	—	—	04W000022

## MATERIALS & SERVICES (TECH TO FILL)

Different Change in Room Temperature

## LABOR DESCRIPTION (TECH TO FILL)

This situation only could be resolve installing a dedicate unit in that area.  
Open port available  
Filters all over are dirty and that could affect the situation of 1 degree differentia if air is not change faster enough

## NOTES

Customer Signature: \_\_\_\_\_ Date: \_\_\_\_\_