



DATE OF ISSUANCE _____

SPECIAL INSPECTION REPORT # _____

PROJECT DATA

SITE INFORMATION

CONTRACTOR

DATE _____ TIME OF ARRIVAL _____, TIME OF DEPARTURE _____ WEATHER _____ T: _____ °F

INSPECTION ITEM _____

STRUCTURAL ELEMENT INSPECTED & WORK LOCATION


CHECK BELOW ANY APPLICABLE OCCURANCES OBSERVED

- ☐ DEVIATIONS FROM THE DESIGN DOCUMENTS
- ☐ ANY SIGNIFICANT OBSERVATIONS CONTRADICTING ANTICIPATED FIELD CONDITIONS
- ☐ ANY WORK IMPROPERLY EXECUTED
- ☐ ANY UNSAFE JOB CONDITIONS
- ☐ ANY PRECAUTIONS TAKEN TO MAINTAIN SAFE CONDITIONS IF WORK WAS STOPPED FOR ANY REASON

NOTES & DESCRIPTION OF SAMPLES OBTAINED IF ANY

Note: Construction and installation nonconformities or discrepancies not included on this report do not imply acceptance. This report does not relieve the contractor or subcontractor of the responsibility of project completion per all applicable codes and standards, approved submittal, approved, plans, or approved technical specifications. This report is subject to a technical review by a professional engineer, based on applicable codes and standards approved project submittals, approved plan, and approved technical specifications, which may result in the issuance of an amended report. To the best of my knowledge, work inspected and tested has been done in accordance with applicable codes and standards, approved project submittal, plans or technical specifications and applicable workmanship provisions of the contract with the exception of that noted above. The results relate only to the items inspected or tested. The report shall not be reproduced, except in full, without the prior written approval of the agency.

Inspector: _____ Supervisor's Signature: _____



FOUNDATION WALL, WEST SIDE

FOUNDATION WALL, NORTH SIDE

HORIZONTAL REINFORCEMENT #5@12"

VERTICAL REINFORCEMENT #5@12"

**5' LENGTH DOWELS LAP SPLICE,
FOUNDATION WALL**

3' 4" HORIZONTAL LAP SPLICE

36" LAP SPLICE IN CORNER

CORNER REINFORCEMENT DETAIL

REBAR #5, VERIFIED IN FIELD

PORTLAND CEMENT TIPE

TREMIE METOD USED FOR GROUTING

BAR IN THE CENTER OF PILE

CERTIFIED WELDER

PILE GROUTED

ELECTRODE USED IN FIELD

GROUT MIXER IN FIELD

ROTARY MACHINE FOR PILE