

DATE OF ISSUANCE \_\_\_\_\_

**SPECIAL INSPECTION REPORT #** \_\_\_\_\_**PROJECT DATA****SITE INFORMATION****CONTRACTOR**

DATE \_\_\_\_\_ TIME OF ARRIVAL \_\_\_\_\_, TIME OF DEPARTURE \_\_\_\_\_ WEATHER \_\_\_\_\_ T: \_\_\_\_\_ °F

INSPECTION ITEM \_\_\_\_\_

STRUCTURAL ELEMENT INSPECTED &amp; WORK LOCATION \_\_\_\_\_

**CHECK BELOW ANY APPLICABLE OCCURANCES OBSERVED**

- ☐ DEVIATIONS FROM THE DESIGN DOCUMENTS
- ☐ ANY SIGNIFICANT OBSERVATIONS CONTRADICTING ANTICIPATED FIELD CONDITIONS
- ☐ ANY WORK IMPROPERLY EXECUTED
- ☐ ANY UNSAFE JOB CONDITIONS
- ☐ ANY PRECAUTIONS TAKEN TO MAINTAIN SAFE CONDITIONS IF WORK WAS STOPPED FOR ANY REASON

**NOTES & DESCRIPTION OF SAMPLES OBTAINED IF ANY**

Note: Construction and installation nonconformities or discrepancies not included on this report do not imply acceptance. This report does not relieve the contractor or subcontractor of the responsibility of project completion per all applicable codes and standards, approved submittal, approved, plans, or approved technical specifications. This report is subject to a technical review by a professional engineer, based on applicable codes and standards approved project submittals, approved plan, and approved technical specifications, which may result in the issuance of an amended report. To the best of my knowledge, work inspected and tested has been done in accordance with applicable codes and standards, approved project submittal, plans or technical specifications and applicable workmanship provisions of the contract with the exception of that noted above. The results relate only to the items inspected or tested. The report shall not be reproduced, except in full, without the prior written approval of the agency.

Inspector: \_\_\_\_\_ Supervisor's Signature: \_\_\_\_\_

**VRF OA-17, OA-18 AND LOUVER**

**VRF BRANCH CONTROLLER**

**EXHAUST DUCT PLENUM**

**FIRE DAMPER, 1ST FLOOR**

**VRF OUTDOOR AIR, 1ST FLOOR**

**VRF OUTDOOR AIR, 1ST FLOOR, 1ST FLOOR**

**VRF INDOOR INDOOR UNITS, 1ST FLOOR**

**VRF INDOOR INDOOR UNITS, 1ST FLOOR  
(NCR-1)**

**AIR CURTAIN FANS, 1ST FLOOR**

**AIR CURTAIN FANS, 1ST FLOOR**

**VRF BRANCH CONTROLLERS, 1ST FLOOR**

**VRF BRANCH CONTROLLERS, 1ST FLOOR  
(NCR-2)**