

**APPROVED**



Approval is always subject to visual  
inspection and final approval on site

Reviewed By *Steve Evans*

Title FPA

Permit # PW 20-015

Date 8/14/2020

## Magnolia Tank Farm - Vehicle Storage - CUP No. 19-023

### Dust Control Plan

For the onsite access roads including the loading and unloading area, and auto storage parking areas - crushed miscellaneous base (CMB) consisting of recycled concrete will be set in place providing a blend of small stones that fit tightly together, forming a stable, solid surface that is dust free and can stand up to heavy vehicles. The suggestion of crushed rock as a dust control measure is based on the California Stormwater (CASQA) BMP Handbook. Below is a table from WE-1: Wind Erosion Fact Sheet showing gravel as acceptable for dust control.

| Site Condition                         | Dust Control Practices |          |                            |                           |                   |                                                             |                  |                                   |
|----------------------------------------|------------------------|----------|----------------------------|---------------------------|-------------------|-------------------------------------------------------------|------------------|-----------------------------------|
|                                        | Permanent Vegetation   | Mulching | Wet Suppression (Watering) | Chemical Dust Suppression | Gravel or Asphalt | Temporary Gravel Construction Entrances/Equipment Wash Down | Synthetic Covers | Minimize Extent of Disturbed Area |
| Disturbed Areas not Subject to Traffic | X                      | X        | X                          | X                         | X                 |                                                             |                  | X                                 |
| Disturbed Areas Subject to Traffic     |                        |          | X                          | X                         | X                 | X                                                           |                  | X                                 |
| Material Stockpiles                    |                        | X        | X                          | X                         |                   |                                                             | X                | X                                 |
| Demolition                             |                        |          | X                          |                           |                   | X                                                           | X                |                                   |
| Clearing/Excavation                    |                        |          | X                          | X                         |                   |                                                             |                  | X                                 |
| Truck Traffic on Unpaved Roads         |                        |          | X                          | X                         | X                 | X                                                           | X                |                                   |
| Tracking                               |                        |          |                            |                           | X                 | X                                                           |                  |                                   |

This method of dust control was reviewed and approved by our civil & geotechnical engineers (reference Grading and Erosion Control plans). See enclosed project plan set and letters.

Previously we suggested utilizing a liquid polymer soil stabilizing product manufactured by Soilworks called Gorilla-Snot. However recommended, we have determined its potential infeasibility due to availability and cost. Crushed rock is being successfully utilized at other auto storage locations and is a superior option regarding dust control. In an effort to keep all alternatives available, we have noted the option for liquid copolymer for the non-access road areas only in-lieu of 2-inches crushed rock.

- Four-inch minimum of crushed rock will be installed over drive aisles (per Grading Plan).
- Two-inch minimum of crushed rock will be installed over auto storage areas (per Grading Plan); or approved liquid copolymer (will provide additional application/maintenance info from manufacturer if utilized).
- During initial delivery, a staff person will be present at all times to visually monitor the air, vehicle speeds, placement of vehicles, and for identification of any potential dust issues.

HBFD  
APPROVED

Date: 08/14/2020

Application of a secondary measure such as truck irrigation using reclaimed water will be utilized, and reapplied if deemed necessary.

- Dust mitigation will be surveyed by the applicant's contractor on a quarterly basis for the first year of operation, with notification to the Huntington Beach Fire Department. If no issues are present, survey frequency can be reduced to a biannual survey. Survey will consist of documentation and compliance with this Dust Control Plan, including measurement of rock to ensure minimum depth (4-inches and 2-inches crushed rock respectively) is maintained for dust control.
- The project will comply with applicable South Coast AQMD Rules including Rule 403 as it applies to any activity capable of generating fugitive dust. Rule 403 requires the implementation of best available dust control measures (BACM) during active operations capable of generating fugitive dust. See link for more info: <https://www.aqmd.gov/docs/default-source/rule-book/rule-iv/rule-403.pdf?sfvrsn=4> . Applicant will investigate all dust complaints submitted to the City or AQMD within 24 hours. The Huntington Beach Fire Department will be notified if any dust control issues should arise. If dust control issues cannot be resolved, air quality samples may be required to ensure air quality is compliant with applicable AQMD Rules. Additionally, the applicant may be required to provide an alternative dust mitigation within one week of unresolvable dust issue.
- The Huntington Beach Fire Department will be notified when dust mitigation (installation) is complete, the Fire Department may inspect as necessary.
- The following contact is provide for resolution of potential complaints:  
Ken Brookins, Service Manager  
Huntington Beach Chrysler Dodge Jeep Ram  
16555 Beach Blvd, Huntington Beach, CA 92647  
W: (714) 841-3999 C: (714) 287-7745 [ken.brookins@hbjeep.com](mailto:ken.brookins@hbjeep.com)

Esquared Planning, Inc.  
Ethan Edwards



LGC Valley, Inc. has reviewed this document from a geotechnical perspective and finds that the recommendations provided in the letter dated June 18, 2020 have been incorporated. Therefore, LGC finds the document is acceptable from a geotechnical point of view.

By: 

Date: July 22, 2020



HBFD  
APPROVED

Date: 08/14/2020