



Prüfzentrum für Bauelemente

Yapı Elemanları Test Enstitüsü

Kapılar • doors
Kepenler • shutters
Pencereler • windows
Cepheler • curtain walling
Yapı Donanımları • building hardware

16.10.2020

Letter of Result / 2020-01-0640-B2

Initial type testing (ITT) of performance characteristics in accordance with EN 14351-1 :2006 + A2 : 2016 “Windows and doors - Product standard, performance characteristics - Part 1: Windows and external pedestrian doorsets”

Applicant	Gürmen PVC Plastik İnş. San.ve Tic. Anonim.Şti Merkez Mah. 89.Sk.No:2 Sasalı – Çiğli / İzmir		
Type	Inward opening tilt and turn single casement window (double glazing)		
System	Proline 81mm Series		
Dimension	Total outside dimensions (W x H)	max.	1180 mm x 1180 mm
	Cesement (W x H)	max.	1097 mm x 1097 mm
Results	Calculation Results for Thermal Calculation According EN10077-2		

Double Glazing U_g	Determined U_w	Rounded U_w
1,1	1,260	1,3

*This document is not a report or a certificate. This document shows the test results. This document is not a certificate for CE-marking. Real reports will be prepared.

Nedret Sürmeli

General Manager

PfB
Prüfzentrum für Bauelemente
Yapı Elemanları Test Merkezi San. ve Tic. Ltd. Şti.
10045 Sokak No: 7 A.O.S.B. Çiğli / İZMİR
Tel: (0.232) 328 10 44
Çiğli Vergi Dairesi - 729 050 7072