



STACK

OBSERVATION TYPE:	Suggestion
INCIDENT DATE:	Thursday, July 17, 2025 2:20 PM
FACILITY:	NVA 05A, Client Vendor
LOCATION DETAILS:	First Floor Corridor, data hall entrance side
INCIDENT ID:	190640
OBSERVATION:	Vendor standing on mid-rail of MEWP



Corrective/Preventative Actions Assigned:

CORRECTIVE / PREVENTATIVE ACTIONS	TARGET DATE	COMPLETION DATE
Spoke with Directline safety supervisor, he posited that as long as they are tied into the lift they can stand on the midrail. Issue has been escalated to COM for further investigation.	07/17/2025	07/17/2025