vDC API properties

Contents

| Basics | 2 |
|--|----|
| Common properties for all addressable Entities | 2 |
| Virtual digitalSTROM device (vdSD) properties | 4 |
| Properties related to the entire device | 4 |
| Button Inputs | 6 |
| Binary Inputs | 8 |
| Outputs | 10 |
| Sensors | 12 |
| Scenes | 14 |
| Control Values | 15 |
| digitalSTROM 1.0 mapping compatibility | 16 |
| 2-way buttons | 17 |
| Multiple vdSDs in a single hardware device | 18 |

Basics

- This document is based on the "vDC API" specification. Please refer to the corresponding document for general description of the API and the available messages/ calls.
- This document specifies the named properties available for different types of addressable entities (vDC, vdSD, vDC host) as well as the properties common for all types of addressable entities.

Common properties for all addressable Entities

- The common properties must be supported by entities which can be addressed via a dSUID using this API (*addressable entities*). At the time of writing, this includes virtual devices, logical vDCs and the vDC host, but may be extended to other entities.
- The "type" property reveals the kind of entity.
- Properties common to a specific entity type are maintained in separate documents. In particular, see "vdSD properties" document for common properties of virtual devices.

| property name | acc | Type/range | description |
|-----------------|-----|----------------|---|
| dSUID | r | string | the dSUID of the entity. Normally not used in regular vDC API calls, as these require the dSUID in the getProperty() call. Useful for debugging. |
| idBlockSize | r | integer | The number of consecutive dSUIDs (starting with this device's dSUID) that are reserved. This means that the next <i>idBlockSize-1</i> dSUIDs are guaranteed not being used by any vdSD in any vDC. This mechanism allows that a vdSM can implement representing multi-input devices as multiple dSUIDs for backwards compatibility with dS 1.0 |
| type | r | string | Type of entity: "vdSD" : virtual dS device "vDC" : a logical vDC "vDChost" : the vDC host "vdSM" : a vdSM |
| model | r | string | human-readable model string of the entity. Should be descriptive enough to allow a human to associate it with a piece of hardware or software |
| hardwareVersion | r | string or NULL | string describing the hardware device's version represented by this entity, if available |

| property name | acc | Type/range | description |
|---------------|-----|----------------|---|
| hardwareGuid | r | string or NULL | hardware's native globally unique identifier (GUID), if any, in URN-like format: formatname:actualID The following formats are in use: • enoceanaddress:XXXXXXXX = 8 hex digits enOcean device address) • gs1:(01)ggggg(21)sssss = GS1 formatted GTIN plus Serial number • uuid:UUUUUUU = UUID • macaddress:MMMMM = MAC Address |
| oemGuid | r | string or NULL | Globaly unique identifier (GUID) of the product the hardware is embedded in, if any - see hardwareGuid for format variants. |
| name | r/w | string | user-specified name of the entity. Is also stored upstreams in the vdSM and further up, but is useful for the vDC to know for configuration and debugging. The vDC usually generates descriptive default names for newly connected devices. When the vdSM registers a device, it should read this property and propagate the name towards the dSS. When the user changes the name via the dSS configurator, this property should be updated with the new name. |

Virtual digitalSTROM device (vdSD) properties

- The following table applies to entities which have a value of "vdSD" for the "type" property.
- All vdSDs must also support the basic set of properties as described under "Common properties" in the "vdSM vDC API" document:
 - dSUID
 - type (value is always "vdSD" for virtual devices"
 - model
 - hardwareVersion
 - hardwareGUID
 - oemGuid
 - name

Properties related to the entire device

| property name | acc | Type/range | description |
|------------------------------------|-----|--------------------------------|--|
| primaryGroup | r | integer, dS group number 18 | basic group (color) of the device |
| outputIsMemberOfGroup [groupNo] | r/w | boolean | array of boolean flags, array index represents the dS group number the output(s) of this device is/are member of. |
| outputLocalPriority | r/w | boolean | enables local priority of the device's output(s). In local priority, device ignores scene calls unless the scene has the <i>ignoreLocalPriority</i> flag set, or the <i>callScene</i> call has the <i>force</i> parameter set to true |
| zoneID | r/w | integer, global dS Zone ID | this should be updated by the vdSM to reflect the zone the device is in. The vDC may use this value to optimize zone calls (i.e. bundle calls to actual hardware if single device calls are slow) |
| progMode | r/w | boolean | enables local programming mode (for those devices that have it) |
| numDevicesInHW | r | optional integer | Number of separate vdSDs that represent the same hardware device (which MUST have the same hardwareGUID) Present only if a unambiguous statement can be made about the number of devices per hardware. Devices that are usually grouped in one chassis, but can be taken apart should not report this property. |

| property name | acc | Type/range | description |
|-----------------|-----|------------------|--|
| deviceIndexInHW | r | optional integer | only if <i>numDevicesInHW</i> exists, this enumerates the devices within the same hardware |

Button Inputs

| property name | acc | Type/range | description |
|---------------------------|-----|--|---|
| buttonInputDescriptions[] | r | object | array of object, representing capabilities of button inputs |
| name | r | string | human readable name/number for the input (e.g. matching labels for hardware connectors) |
| supportsLocalKeyMode | r | boolean | can be local button |
| buttonID | r | integer 0n (optional) | ID of physical button. No ID means no fixed assignment to a button. All elements of a multi-function hardware button must have the same buttonID. |
| buttonType | r | integer enum (inputs with buttons supported only) | Type of physical button 0: undefined 1: single pushbutton 2: 2-way pushbutton 3: 4-way navigation button 4: 4-way navigation with center button 5: 8-way navigation with center button 6: on-off switch |
| buttonElementID | r | integer (inputs with buttons supported only) | Element of multi-contact button: 0: center 1: down 2: up 3: left 4: right 5: upper left 6: lower left 7: upper right 8: lower right Note: For undefined buttonType, buttonElement just enumerates the elements (0numElements-1) |
| buttonInputSettings[] | r/w | object | array of objects, representing configuration settings of buttons and binary inputs |
| group | r/w | integer | dS group number 18 |
| function | r/w | integer 015 | see LTNUM descriptions (0: device, 5: room,) |
| mode | r/w | integer | 255: inactive 0: standard 2: presence 58: button14 down 912: button14 up |
| setsLocalPriority | r/w | boolean | button should set local priority |
| callsPresent | r/w | boolean | button should call present (if system state is absent) |

| property name | acc | Type/range | description |
|---------------------|-----|-----------------|---|
| buttonInputStates[] | r | object | representation of the current state of the button |
| value | r | boolean or NULL | false=inactive, true=active, NULL=unknown state |
| clickType | r | integer enum | Most recent click state of the button: 0: tip_1x 1: tip_2x 2: tip_3x 3: tip_4x 4: hold_start 5: hold_repeat 6: hold_end 7: click_1x 8: click_2x 9: click_3x 10: short_long 11: local_off 12: local_on 13: short_short_long 14: local_stop 255: idle (no recent click) |
| age | r | double or NULL | age of the state shown in the <i>value</i> and <i>clickType</i> fields in seconds. If no recent state is known, returns NULL. |
| error | r | integer enum | 0: ok 1: open circuit 2: short circuit 4: bus connection problem 5: low battery in device 6: other device error |

Binary Inputs

| property name | acc | Type/range | description |
|---------------------------|-----|--|--|
| binaryInputDescriptions[] | r | object | array of object, representing capabilities of binary inputs |
| name | r | string | human readable name/number for the input (e.g. matching labels for hardware connectors) |
| inputType | r | integer (inputs with binary functions supported only) | 0: poll only 1: detects changes |
| inputUsage | r | integer enum | Describes the usage field for the input (beyond device color) 0: undefined (generic usage or unknown) 1: room climate 2: outdoor climate 3: climate setting (from user) |
| hardwareSensorFunction | r | integer enum | hardwired function of this input if it is not freely configurable. See sensorFunction in binaryInputSettings[] below for possible values. O means generic input with no hardwaredefined functionality. |
| updateInterval | r | double | how fast the physical value is tracked, in seconds |
| binaryInputSettings[] | r/w | object | array of objects, representing configuration settings of buttons and binary inputs |
| group | r/w | integer | dS group number 18 |
| sensorFunction | r/w | integer enum | 0x00 App Mode (no system function) 0x01 Presence (Präsenz) 0x02 Light (Helligkeit) – aktuell noch nicht in Verwendung 0x03 Presence in darkness (Präsenz bei Dunkelheit) – aktuell noch nicht in Verwendung 0x04 Twilight (Dämmerung) 0x05 Motion detector (Bewegung) 0x06 Motion in darkness (Bewegung bei Dunkelheit) – aktuell noch nicht in Verwendung 0x07 Smoke detector (Rauchmelder) 0x08 Wind monitor (Windwächter) 0x09 Rain monitor (Regenwächter) 0x0a Solar radiation (Sonneneinstrahlung) 0x0b Thermostat (Thermostat) |
| binaryInputStates[] | r | object | representation of the current state of the inputs |
| value | r | boolean or NULL | false=inactive, true=active, NULL=undefined |

| property name | acc | Type/range | description |
|---------------|-----|----------------|---|
| age | r | double or NULL | age of the state shown in the <i>value</i> field in seconds. If no recent state is known, returns NULL |
| error | r | integer enum | 0: ok 1: open circuit 2: short circuit 4: bus connection problem 5: low battery in device 6: other device error |

Outputs

| property name | acc | Type/range | description |
|----------------------|-----|--------------|--|
| outputDescriptions[] | r | object | array of objects, representing hardware capabilities of output |
| name | r | string | human readable name/number for the output (e.g. matching labels for hardware connectors) |
| function | r | integer enum | 0: on/off only 1: dimmer 2: positional |
| outputUsage | r | integer enum | Describes the usage field for the output (beyond device color) 0: undefined (generic usage or unknown) 1: room 2: outdoors 3: user (display/indicator) |
| variableRamp | r | boolean | supports variable ramps |
| maxPower | r | integer | max output power in Watts. If absent, power capability is undefined |
| minDim | r | integer | minmum brightness that hardware supports (for dimming outputs) |
| outputSettings[] | r/w | object | array of objects, representing operation mode of output |
| group | r/w | integer | dS group number 18 |
| mode | r/w | integer enum | 0: disabled, inactive 1: binary 2: gradual |
| pushChanges | r/w | boolean | if set, locally generated changes in the output value will be pushed |
| dimTimeUp | r/w | integer | dim up time in ms |
| dimTimeDown | r/w | integer | dim down time in ms |
| dimTimeUpAlt1 | r/w | integer | alternate 1 dim up time in ms |
| dimTimeDownAlt1 | r/w | integer | alternate 1 dim down time in ms |
| dimTimeUpAlt2 | r/w | integer | alternate 2 dim up time in ms |
| dimTimeDownAlt2 | r/w | integer | alternate 2 dim down time in ms |
| outputStates[] | r/w | object | array of output states |
| value | r/w | integer | current output value (brightness, blind position, on/off) |

| property name | acc | Type/range | description |
|---------------|-----|--------------|---|
| age | r | double | age of the state shown in the <i>value</i> field in seconds. This indicates when the value was last applied to the actual device hardware, or when an actual output status was last received from the device. <i>age</i> is NULL when a new value was set, but not yet applied to the device |
| error | r | integer enum | 0: ok 1: open circuit / lamp broken 2: short circuit 3: overload 4: bus connection problem 5: low battery in device 6: other device error |

Sensors

| property name | acc | Type/range | description |
|----------------------|-----|----------------|--|
| sensorDescriptions[] | r | object | description of sensor capabilities |
| name | r | string | human readable name/number for the sensor |
| sensorType | r | integer enum | Describes the type of physical unit the sensor measures 0: none 1: temperature in °C 2: relative humitity in % 3: illumination in lux 4: supply voltage level in V 5: CO concentration in ppm 6: Radon activity in Bq/m3 7: gas type sensor 8: particles <10μm in μg/m3 9: particles <2.5μm in μg/m3 10: particles <1μm in μg/m3 11: room operating panel set point, 01 12: fan speed, 01 (0=off, <0=auto) 13: wind speed in m/s |
| sensorUsage | r | integer enum | Describes the usage field for the sensor 0: undefined (generic usage or unknown) 1: room 2: outdoor 3: user (setting, dial) |
| min | r | double | min value |
| max | r | double | max value |
| resolution | r | double | resolution (size of LSB of actual HW sensor) |
| updateInterval | r | double | how fast the physical value is tracked, in seconds |
| sensorSettings[] | r/w | object | sensor configuration |
| group | r/w | integer | dS group number 18 |
| minPushInterval | r/w | double | minimum interval between pushes of changed state in seconds, default=2 |
| changesOnlyInterval | r/w | double | minimum interval between pushes with same value (in case sensor hardware sends update, but with same value as before - only age will differ). default=0=all updates from hardware trigger a push |
| sensorStates[] | r | object | sensor states |
| value | r | double or NULL | current sensor value in the unit specified in SensorCapabilities.unit If no recent state is known, returns NULL. |

| property name | acc | Type/range | description |
|---------------|-----|----------------|---|
| age | r | double or NULL | age of the state shown in the <i>value</i> field in seconds. If no recent state is known, returns NULL |
| error | r | integer enum | 0: ok 1: open circuit 2: short circuit 4: bus connection problem 5: low battery in device 6: other device error |

Scenes

| property name | acc | Type/range | description |
|---------------------|-----|---|--|
| scenes[] | r/w | object | array of saved device states that can be recalled via callScene. Index is scene number |
| value | r/w | optional integer (or NULL when writing to actively delete the value from the scene) | primary output value for this scene (usually brightness). If value is not present, calling scene does not affect corresponding output value (Note that scene-level <i>dontCare</i> flag can be used to prevent applying any scene values) |
| valueN | r/w | optional integer (or NULL when writing to actively delete the value from the scene) | with N=1x - secondary values, like blind angle etc., depending on device types. If value is not present, calling scene does not affect corresponding output value (Note that scene-level dontCare flag can be used to prevent applying any scene values) |
| dontCare | r/w | boolean | calling this scene does not apply the stored output values |
| ignoreLocalPriority | r/w | boolean | calling this scene overrides local priority |
| flashing | r/w | boolean | calling this scene blinks the output |
| dimTimeSelector | r/w | integer 02 | selects the dimming time: • 0 = use dimTimeUp/dimTimeDown • 1 = use dimTimeUpAlt1/dimTimeDownAlt1 • 2 = use dimTimeUpAlt2/dimTimeDownAlt2 |
| other_scene_value | | | scenes might contain additional device specific scene values not currently used by the dS system |

Control Values

Control Values are not regular properties, but like properties, control values are named values and thus similar to properties. Unlike properties, control values cannot be read but only written to a vdSD, using the *setControlValue* call.

| control value name | Туре | description |
|--------------------|--------|--|
| heatingLevel | double | (dS Sensortype 50): level of heating intensity -100100: 0=no heating or cooling, 100=max heating, -100 max cooling |

digitalSTROM 1.0 mapping compatibility

An important design goal for the vDC API and the vdSD property set was to avoid carrying over dS 1.0 specific limitations.

On the other hand, the vDC API was designed to support capabilities current dSS 1.x architecture can't support yet, but are likely to be implemented in future dS versions.

Still, the vDC + vdSM needs to be compatible with existing dSS 1.x installations.

To achieve this, vDC devices (vdSDs) that provide functionality similar or equal to existing hardware digitalSTROM devices (dSDs), must have sensible default settings that make them mappable into existing dSS 1.x installations.

This chapter lists the conventions that must be followed for certain device types to make them mappable into dSS 1.x environments.

2-way buttons

2-way buttons (rockers) like present in many enOcean devices must conform to the following default behaviour:

- 1. the vdSD must have two button inputs (represented by 2 array elements in the buttonInputDescriptions/Settings/States property arrays)
- 2. the buttonInput with index = 0 must represent the "down" button
- 3. the buttonInput with index = 1 must represent the "up" button
- 4. buttonInputSettings[0].mode must be 6 (down button paired with second input)
- 5. buttonInputSettings[1].mode must be 9 (up button paired with first input)
- 6. in the dSUID space, the dSUID following the dSUID of the device (device's dSUID + 1) must be guaranteed unused. This means that the *idBlockSize* property must be 2 to document that the next dSUID is guaranteed unused. This *allows* the vdSM to virtually split the device into two separate dSUIDs to mimic for example a SW-TKM210 towards the dSS 1.x environment. The vdSM *may* also choose to represent the device as a single dSUID with a inseparable 2-way button instead, like a GR-TKM210.

Multiple vdSDs in a single hardware device

Some hardware devices contain more than one instance of a certain functional unit. Usually, these are represented as a separate vdSD each, to allow maximum flexibility in the way the functional units can be used.

For example, a dual 2-way button enOcean device will be represented as 2 entirely separate vdSDs, because despite the physical proximity, each button might conrol a different zone, group or function. By default, such a device will be represented as 2 separate SW-TKM210 (dual input) devices. However, the vdSM might want to represent it as a single SW-TKM200 (quad input) device. To allow the vdSM to find out which and how many vdSDs are in the same hardware device, the vdSD *should* expose this information in the *numDevicesInHW* and *deviceIndexInHW* properties as follows:

- 1. numDevicesInHW contains the number of vdSDs in the same hardware device
- 2. hardware GUID identifies the hardware device of which the vdSD is part of
- 3. deviceIndexInHW contains an index, 0..numDevicesInHW-1 that enumerates the vdSDs in the same hardware device
- 4. This association of vdSDs to a containing hardware device must only be made when the number of grouped vdSDs and enumeration is unambiguous and permanent. So just 3 modules that usually ship mounted on a common frame, but can be easily separated and used independently should not have numDevicesInHW and deviceIndexInHW properties.