Electrical Distribution

Main | Chiller | Air | Electrical

Time selector for electrical analytics and trend

Last Day | Trend: Power (kW)

Electrical Overview

Main Power
1160.92 kW
Period end: 08/04/2569 15:02:11

Main Energy Consumption
1401.45 kWh
Delta from main meter over selected range

Total Floor Energy
280.67 kWh
Sum of floor meter energy over selected range

Avg Power Factor
0.906
Average of main and floor power factors

Consumption Breakdown per Floor

Floor 1

Power	45.33 kW
Energy	70.35 kWh
Current	70.75 A
Power Factor	0.906

Floor 2

Power	44.63 kW
Energy	69.74 kWh
Current	69.89 A
Power Factor	0.906

Floor 3

Power	44.99 kW
Energy	70.08 kWh
Current	69.61 A
Power Factor	0.906

Floor 4

Power	45.03 kW
Energy	70.50 kWh
Current	70.80 A
Power Factor	0.906

Individual Equipment Power and Energy Monitoring

Chillers

CH-1

Power	254.60 kW
Energy	709.44 kWh
Current	396.44 A
Voltage L-L Avg	403.03 V
Power Factor	0.906

CH-2

Power	258.40 kW
Energy	121.07 kWh
Current	402.35 A
Voltage L-L Avg	403.03 V
Power Factor	0.906

CH-3

Power	256.98 kW
Energy	146.73 kWh
Current	400.14 A
Voltage L-L Avg	403.03 V
Power Factor	0.906

CHW Pumps

CHWP-1	
Power	30.07 kW
Energy	34.37 kWh
Current	46.82 A
Voltage L-L Avg	403.03 V
Power Factor	0.906

CHWP-2	
Power	28.50 kW
Energy	12.34 kWh
Current	44.38 A
Voltage L-L Avg	403.03 V
Power Factor	0.906

CHWP-3	
Power	28.47 kW
Energy	15.47 kWh
Current	44.33 A
Voltage L-L Avg	403.03 V
Power Factor	0.906

Condenser Pumps

CDP-1	
Power	37.06 kW
Energy	44.80 kWh
Current	57.71 A
Voltage L-L Avg	403.03 V
Power Factor	0.906

CDP-2	
Power	34.42 kW
Energy	17.94 kWh
Current	53.60 A
Voltage L-L Avg	403.03 V
Power Factor	0.906

CDP-3	
Power	37.33 kW
Energy	21.06 kWh
Current	58.13 A
Voltage L-L Avg	403.03 V
Power Factor	0.906

Cooling Towers

CT-1	
Power	4.88 kW
Energy	6.24 kWh
Current	7.60 A
Voltage L-L Avg	403.03 V
Power Factor	0.906

CT-2	
Power	5.88 kW
Energy	2.81 kWh
Current	9.16 A
Voltage L-L Avg	403.03 V
Power Factor	0.906

CT-3	
Power	6.66 kW
Energy	3.12 kWh
Current	10.37 A
Voltage L-L Avg	403.03 V
Power Factor	0.906

AHU Meters

AHU-1	
Power	18.71 kW
Energy	27.51 kWh
Current	29.13 A
Voltage L-L Avg	403.03 V
Power Factor	0.906

AHU-2	
Power	18.75 kW
Energy	27.42 kWh
Current	29.20 A
Voltage L-L Avg	403.03 V
Power Factor	0.906

AHU-3	
Power	18.23 kW
Energy	27.23 kWh
Current	28.39 A
Voltage L-L Avg	403.03 V
Power Factor	0.906

AHU-4	
Power	18.76 kW
Energy	27.70 kWh
Current	29.21 A
Voltage L-L Avg	403.03 V
Power Factor	0.906

Electrical Trend


Main Power (kW)
Floor 1 Power (kW)
Floor 2 Power (kW)
Floor 3 Power (kW)
Floor 4 Power (kW)
1,200
1,000
800
600
400
200
0
07/04 19:00
07/04 20:00
07/04 21:00
07/04 22:00
07/04 23:00
08/04 00:00
08/04 01:00
08/04 02:00
08/04 12:00
08/04 13:00
08/04 14:00