

BUSHING INSULATION POWER FACTOR REPORT



Equipment Name	GTG41 GSUT	Site	SITE2
Serial No.	6310537	Power Rating	65000 kVA
Manufacture	TIRATHAI	Voltage Rating	120 /11 / kV
Fluid Type	Mineral Oil	Service Type	GSUT

Test Information				Enviroment	
Test Instrument	CPC100, CP TD1			Ambient Temp.	30 °C
Serial Number	UA353B			Oil Temp.	30 °C
Calibration Date	0-Jan-1900			Winding Temp.	30 °C
				Humidity.	56 %

Bushings Nameplate Informaion									
Phase	MFG.	Serial No.	Model	Age	Type	%PF (C1)	Cap.(pF) C1	%PF (C2)	Cap.(pF) C2
H1	TRENCH	21B4889	COTC550-800L0	5	OIP	0.23	166	0.34	117
H2	TRENCH	21B4890	COTC550-800L0	5	OIP	0.24	166	0.33	119
H3	TRENCH	21B4891	COTC550-800L0	5	OIP	0.23	167	0.29	115
H0	-	-	-	-	-	-	-	-	-
X1	-	-	-	-	-	-	-	-	-
X2	-	-	-	-	-	-	-	-	-
X3	-	-	-	-	-	-	-	-	-
X0	-	-	-	-	-	-	-	-	-

HV Bushing Power Factor										
Test Voltage (C1) 10 kV				Test Voltage (C2) kV						
Test Connection				Current (mA)	Power (mW)	Power Factor			Capacitance	
Measured	Energize	GST	GSTg			Meas. (%)	at 20°C (%)	Error (%)	Meas. (pF)	Error (%)
H1 (C1)	H1	BT	-	0.52	11.78	0.2277	0.250	8.9	164.3	1.02
H1 (C2)	BT	-	H1				-	-		-
H2 (C1)	H2	BT	-	0.51	11.28	0.2194	0.241	0.6	163.5	1.51
H2 (C2)	BT	-	H2				-	-		-
H3 (C1)	H3	BT	-	0.52	11.42	0.2200	0.242	5.2	165	1.20
H3 (C2)	BT	-	H3				-	-		-
H0 (C1)	H0	BT	-	-			-	-		-
H0 (C2)	BT	-	H0	-	-	-	-	-	-	-

LV Bushing Power Factor										
Test Voltage (C1) - kV				Test Voltage (C2) - kV						
Test Connection				Current (mA)	Power (mW)	Power Factor			Capacitance	
Measured	Energize	GST	GSTg			Meas. (%)	at 20°C (%)	Error (%)	Meas. (pF)	Error (%)
X1 (C1)	X1	BT	-				-	-		-
X1 (C2)	BT	-	X1				-	-		-
X2 (C1)	X2	BT	-				-	-		-
X2 (C2)	BT	-	X2				-	-		-
X3 (C1)	X3	BT	-				-	-		-
X3 (C2)	BT	-	X3				-	-		-
X0 (C1)	X0	BT	-				-	-		-
X0 (C2)	BT	-	X0	-	-	-	-	-	-	-

Criteria:										
Bushing Type	IEEEC57.152-2013		ABB		TRENCH		PASSONI VILLA		MGC	
	Error %PF (C1)	Error Cap (C1)	Error %PF (C1)	Error Cap (C1)	Error %PF (C1)	Error Cap (C1)	Error %PF (C1)	Error Cap (C1)	Error %PF (C1)	Error Cap (C1)
OIP	1.5-2 time	<5%	<75%	<3%	Double	<110%	-	-	-	-
RIP	1.5-2 time	<5%	<75%	<3%	-	-	<30%	<1%	<10%	< 0.7%
RIS	-	-	-	-	-	-	-	-	-	-

Response	Tested By	Reviewed By	Approved By
Company	GPSC		
Name	Jirasak S.		
Signature			
Date	26-Nov-2025	26-Nov-2025	26-Nov-2025