


# SURGE ARRESTER POWER FACTOR REPORT



|                |              |                |                          |
|----------------|--------------|----------------|--------------------------|
| Equipment Name | 14100-TR-003 | Site           | CUP-1                    |
| Serial No.     | PP0084B01    | Power Rating   | 40000 kVA                |
| Manufacture    | DAIHEN       | Voltage Rating | 115 /22 / kV             |
| Fluid Type     | Mineral Oil  | Service Type   | Distribution Transformer |

| Test Information |              | Enviroment    |       |
|------------------|--------------|---------------|-------|
| Test Instrument  | TESTRANO 600 | Ambient Temp. | 31 °C |
| Serial Number    | DA193X       | Oil Temp.     | 30 °C |
| Calibration Date | 2025-12-15   | Winding Temp. | 30 °C |
|                  |              | Humidity.     | 71 %  |

| Bushing Informaion |            |              |                |                 |              |                |                 | Method Test                                                                         |
|--------------------|------------|--------------|----------------|-----------------|--------------|----------------|-----------------|-------------------------------------------------------------------------------------|
| Phase              | Serial No. | Layer 1      |                |                 | Layer 2      |                |                 |  |
|                    |            | Current (mA) | Watt Loss (mW) | Resistance (MΩ) | Current (mA) | Watt Loss (mW) | Resistance (MΩ) |                                                                                     |
| H1                 | 48013      | 0.16         | 109.2          | -               | -            | -              | -               | 1                                                                                   |
| H2                 | 48013      | 0.15         | 105.44         | -               | -            | -              | -               |                                                                                     |
| H3                 | 48015      | 0.17         | 109.25         | -               | -            | -              | -               | 2                                                                                   |
| H0                 | -          | -            | -              | -               | -            | -              | -               |                                                                                     |
| X1                 | -          | -            | -              | -               | -            | -              | -               | 2                                                                                   |
| X2                 | -          | -            | -              | -               | -            | -              | -               |                                                                                     |
| X3                 | -          | -            | -              | -               | -            | -              | -               | 2                                                                                   |
|                    |            | -            | -              | -               | -            | -              | -               |                                                                                     |

| HV Bushing Power Factor   |          |     |      |                 |        |      |            |        |      |            |
|---------------------------|----------|-----|------|-----------------|--------|------|------------|--------|------|------------|
| Test Voltage <u>10</u> kV |          |     |      |                 |        |      |            |        |      |            |
| Test Connection           |          |     |      | Leakage Current |        |      | Watt Loss  |        |      | Resistance |
| Measured                  | Energize | GST | GSTg | Meas. (mA)      | %Error | %Dev | Meas. (mW) | %Error | %Dev | (MΩ)       |
| H1 (Layer 1)              | 1        | 2   | -    | 0.16            | -      | -    | 136.94     | -      | -    | 12500      |
| H2 (Layer 1)              | 1        | 2   | -    | 0.15            | -      | -    | 128.39     | -      | -    | 13200      |
| H3 (Layer 1)              | 1        | 2   | -    | 0.15            | -      | -    | 127.01     | -      | -    | -          |
| H0 (Layer 1)              | 1        | 2   | -    | -               | -      | -    | -          | -      | -    | -          |
| H1 (Layer 2)              | 1        | -   | 3    | -               | -      | -    | -          | -      | -    | -          |
| H2 (Layer 2)              | 1        | -   | 3    | -               | -      | -    | -          | -      | -    | -          |
| H3 (Layer 2)              | 1        | -   | 3    | -               | -      | -    | -          | -      | -    | -          |
| H0 (Layer 2)              | 1        | -   | 3    | -               | -      | -    | -          | -      | -    | -          |

| HV Bushing Power Factor        |          |     |      |                 |        |      |            |        |      |            |
|--------------------------------|----------|-----|------|-----------------|--------|------|------------|--------|------|------------|
| Test Voltage (C1) <u>10</u> kV |          |     |      |                 |        |      |            |        |      |            |
| Test Connection                |          |     |      | Leakage Current |        |      | Watt Loss  |        |      | Resistance |
| Measured                       | Energize | GST | GSTg | Meas. (mA)      | %Error | %Dev | Meas. (mW) | %Error | %Dev | (MΩ)       |
| H1 (Layer 1)                   | 1        | 2   | -    | #VALUE!         | -      | -    | #VALUE!    | -      | -    |            |
| H2 (Layer 1)                   | 1        | 2   | -    | #VALUE!         | -      | -    | #VALUE!    | -      | -    |            |
| H3 (Layer 1)                   | 1        | 2   | -    | #VALUE!         | -      | -    | #VALUE!    | -      | -    |            |
| H1 (Layer 2)                   | 1        | -   | 3    | -               | -      | -    | -          | -      | -    | -          |
| H2 (Layer 2)                   | 1        | -   | 3    | -               | -      | -    | -          | -      | -    | -          |
| H3 (Layer 2)                   | 1        | -   | 3    | -               | -      | -    | -          | -      | -    | -          |

|                                         |                                   |
|-----------------------------------------|-----------------------------------|
| Criteria: EGAT                          |                                   |
| %Dev Leakage Current : < 20% = Normal   | %Dev Watt Loss : < 20% = Normal   |
| %Error Leakage Current : < 50% = Normal | %Error Watt Loss : < 50% = Normal |
| Minimum Insulation Resistance 10,000 MΩ |                                   |

| Response  | Tested By     | Reviewed By | Approved By   |
|-----------|---------------|-------------|---------------|
| Company   | GPSC          |             | GPSC          |
| Name      | Mr.Jirasak S. |             | Mr.Suchart M. |
| Signature |               |             |               |
| Date      | 16-Jul-2026   | 16-Jul-2026 | 16-Jul-2026   |