

HIGH VOLTAGE EXCITING CURRENT REPORT



Equipment Name	14100-TR-004	Site	CUP-1
Serial No.	PP0102B01	Power Rating	40000 kVA
Manufacture	DAIHEN	Voltage Rating	115 /22 / kV
Fluid Type	Mineral Oil	Service Type	Distribution Transformer

Test Information

Test Instrument	TESTRANO 600
Serial Number	DA193X
Calibration Date	2025-12-15

Environment

Ambient Temp.	_____ °C
Oil Temp.	_____ °C
Winding Temp.	_____ °C
Humidity.	_____ %

Test connection

Vector Group: Dyn1 High-Low-High
HV side is Wye-Connected (Y)

Voltage Rated	3-5 kV	> 5-12 kV	> 12 kV
AC Test Voltage	2.5 kV	5 kV	10 kV

Test No.	Measured	Energized	UST	Float	Ground
1	H1-H0	H1	H0	All others	*
2	H2-H0	H2	H0	All others	*
3	H3-H0	H3	H0	All others	*

* if LV side is Wye-connect, X0 is grounded.

HV side is Delta-Connected (Δ)

Test No.	Measured	Energized	UST	Float	Ground
1	H1-H2	H1	H2	X1,X2,X3	H3*
2	H2-H3	H2	H3	X1,X2,X3	H1*
3	H3-H1	H3	H1	X1,X2,X3	H2*

* if LV side is Wye-connect, X0 is grounded.

Primary Winding Test

Test Voltage 10 kV

Pattern: High-Low-High

Normal Pattern

Tap position	Connection: H1-H2			Connection: H2-H3			Connection: H3-H1		
	Com. (mA)	Measured (mA)	%Error	Com. (mA)	Measured (mA)	%Error	Com. (mA)	Measured (mA)	%Error
Max	12.20	13.591	11.40	3.90	4.083	4.69	12.20	13.74	12.60
Center	14.60	16.12	10.40	4.70	4.824	2.64	14.7	16.358	11.28
Min	17.70	19.408	9.65	5.80	5.78	0.34	17.80	19.676	10.54
Tap: -	-	-	-	-	-	-	-	-	-
Tap: -	-	-	-	-	-	-	-	-	-
Max %error similar phase						-	Max %error lower phase		
						-			

Secondary Winding Test

Test Voltage - V

Tap position	Connection: X1-X0			Connection: X2-X0			Connection: X3-X0		
	Com. (mA)	Measured (mA)	%Error	Com. (mA)	Measured (mA)	%Error	Com. (mA)	Measured (mA)	%Error
-	-	-	-	-	-	-	-	-	-
Max %error similar phase						0.00	Max %error lower phase		
						0.00			

Tertiary Winding Test

Test Voltage - V

Tap position	Connection: Y1-Y0			Connection: Y2-Y0			Connection: Y3-Y0		
	Com. (mA)	Measured (mA)	%Error	Com. (mA)	Measured (mA)	%Error	Com. (mA)	Measured (mA)	%Error
-	-	-	-	-	-	-	-	-	-
Max %error similar phase						0.00	Max %error lower phase		
						0.00			

Criteria: IEEE C57.152-2013

Vector Group (3Ø Core Type)	Current Pattern (Primary Winding)	Vector Group (3Ø Core Type)	Current Pattern (Primary Winding)
Dyn1	High-Low-High	YNd1	High-Low-High
Dyn11	High-Low-High	YNd5	High-Low-High
YNd0(d1)	High-Low-High	YNd11	High-Low-High
YNyn0(d1)	High-Low-High	YNyn0	High-Low-High

Response	Tested By	Reviewed By	Approved By
Company	GPSC		GPSC
Name	Mr.Jirasak S.		Mr.Suchart M.
Signature			
Date	46224	21-Jul-2026	21-Jul-2026