

INSULATION RESISTANCE AND PI REPORT



Equipment Name	2GTB-XF-1.30.EN	Site	SITE3
Serial No.	57012	Power Rating	215000 kVA
Manufacture	ABB	Voltage Rating	118 /15.75 kV
Fluid Type	Mineral Oil	Service Type	GSUT

Test Information				Environment	
Test Instrument	-			Ambient Temp.	28 °C
Serial Number	101716389			Oil Temp.	34 °C
Calibration Date	0000-00-00			Winding Temp.	34 °C
				Humidity.	67 %

Primary Winding Test [HV-(LV&TV+GND)]										
Test Voltage - Vdc				Voltage Rated (V)		≤ 100	440-550	2,400	> 2,400	
				DC Test Voltage (V)		100-250	500 - 1,000	1,000-2,500	1,000-5,000	
Min.1 (MΩ)	Min.2 (MΩ)	Min.3 (MΩ)	Min.4 (MΩ)	Min.5 (MΩ)	Min.6 (MΩ)	Min.7 (MΩ)	Min.8 (MΩ)	Min.9 (MΩ)	Min.10 (MΩ)	PI
-									-	-

Secondary Winding Test [LV-(HV&TV+GND)]										
Test Voltage 2500 Vdc										
Min.1 (MΩ)	Min.2 (MΩ)	Min.3 (MΩ)	Min.4 (MΩ)	Min.5 (MΩ)	Min.6 (MΩ)	Min.7 (MΩ)	Min.8 (MΩ)	Min.9 (MΩ)	Min.10 (MΩ)	PI
1661	1975	2170	2330	2450	2580	2680	2770	2860	2930	1.76

Tertiary Winding Test [TV-(HV&LV+GND)]										
Test Voltage - Vdc										
Min.1 (MΩ)	Min.2 (MΩ)	Min.3 (MΩ)	Min.4 (MΩ)	Min.5 (MΩ)	Min.6 (MΩ)	Min.7 (MΩ)	Min.8 (MΩ)	Min.9 (MΩ)	Min.10 (MΩ)	PI
-									-	-

Core Insulation Test										
Test Voltage - Vdc										
CORE-GROUND MΩ				FRAME(CLAMP)-GROUND MΩ				CORE-FRAME(CLAMP) MΩ		
-				-				-		

Criteria: IEEE C57.152-2013

Polarization Index (PI)	Condition
≤ 1.0	Dangerous
1.0 - 1.1	Poor
1.1 - 1.25	Questionable
1.25 - 2.0	Fair
> 2.0	Good

Type		Condition
New TR	> 500	Normal
Service aged	> 100	Normal
	10 - 100	Insulation deterioration
	< 10	Needs to be investigated

Response	Tested By	Reviewed By	Approved By
Company	GPSC		
Name	Mr.Jirasak S.		
Signature			
Date	19-Mar-22	19-Mar-22	19-Mar-22