

## PUMP TEST REPORT


Invoice Number:	12
Customer:	Madorido
Job Number:	12

FABRICATION		HYDRAULIC TEST	
Pump Model:	P1 1.1KW	Date of Test:	2025-03-17
Serial Number:	4101 001 - 25	Duration of Test:	1
Impeller Diameter:	1	Test Medium:	1
Assembled By:	tester1	Tested By:	tester1

DETAILS			
Motor Size:		Frequency:	
Motor Speed:		Pump Housing:	
Motor Volts:		Pump Connection:	
Motor Enclosure:		Suction:	
Mechanical Seal:		Discharge:	
		Flush Arrangement:	No

### TEST RESULTS

Test	Flowrate (L/h)	Pressure (bar)	Amperage (A)
Test 1	17912	2.85	6.19
Test 2	12050	3.05	5.52
Test 3	8078	3.05	5.2
Test 4	4089	3.05	3.05
Test 5	0	3.05	4.74



APPROVAL			
Approved By:	1		
Date:	2025-03-17		