


## PUMP TEST REPORT

Invoice Number:	1
Customer:	Madorido
Job Number:	1

FABRICATION		HYDRAULIC TEST	
Pump Model:	PT 0.55KW	Date of Test:	2025-03-17
Serial Number:	1101 004 - 25	Duration of Test:	1
Impeller Diameter:	1	Test Medium:	1
Assembled By:	tester1	Tested By:	tester1

DETAILS			
Motor Size:	1	Frequency:	1
Motor Speed:	1	Pump Housing:	1
Motor Volts:	1	Pump Connection:	11
Motor Enclosure:	1	Suction:	1
Mechanical Seal:	1	Discharge:	1
		Flush Arrangement:	No

TEST RESULTS			
Test	Flowrate (L/h)	Pressure (bar)	Amperage (A)
Test 1	17912	2.85	6.19
Test 2	12050	3.05	5.52
Test 3	8078	3.05	5.2
Test 4	4089	3.05	4.87
Test 5	0	3.05	4.74



APPROVAL			
Approved By:	1		
Date:	2025-03-17		