

ECO-VAC



INSTALLATION AND SERVICE MANUAL

Revised 6-13

***TW* TECH WEST INC.**

Manufacturers of Dental Vacuum
and Air Systems

2625 N. Argyle Ave. • Fresno, CA 93727
(559) 291-1650 • (800) 428-7139 • FAX (559) 348-9677
www.tech-west.com

This manual is for the installation and service of Tech West's Eco-Vac Dry Vacuums.

ECO-VAC

INSTALLATION AND SERVICE MANUAL



CONTENTS

Location & Voltage Requirements	1
Installation	2
Plumbing	3
Vacuum & Line Sizing	4
Connections	5
Wiring Diagram	6
Physical Schemeatic	7-8
Motor Breakdown	9
Notes	10

ECO-VAC LOCATION REQUIREMENTS

The Eco-Vac Dry Vacuum location should be level, accessible and well ventilated.

If the Eco-Vac Dry Vacuum will be located in a confined space, provide adequate ventilation and

Install an exhaust fan. **THE EXHAUST VENT ON THE VACUUM UNIT MUST BE CONNECTED TO A LOCATION OUTSIDE OF THE EQUIPMENT LOCATION. THE CONNECTION CAN BE MADE WITH SCHEDULE 40 OR 80 PVC.**

The following utilities are required:

- 1) The vacuum system can be run in the following temperature range.

Minimum air temperature 40 degrees F./ 4.5 degrees C.

Maximum air temperature 100 degrees F./37.75 degrees C.

Running the vacuum outside of this range will VOID the warranty and can damage to the system.

- 2) Waste Disposal **THE VACUUM SYSTEM MUST BE INSTALLED SO THAT THE DRAIN ON THE SIDE OF THE UNIT IS HIGHER THAT THE WASTE CONNECTION. THIS WILL ALLOW THE UNIT TO GRAVITY DRAIN WHEN THE SUCTION IS SHUT OFF.** Provide a floor sink or trapped sewer line to connect the 1 1/4" PVC flex hose included in the hook-up kit. Provide exhaust vent sized according to table 1 below and waste drain that complies with local code.
- 3) Vacuum Line The main vacuum line from the operatories must connect to the Eco-Vac. Connect to the piping using the 1 1/4" PVC hose provided in the hook-up kit.
- 4) **Electrical-CAUTION:** "possible ground leakage current present" "présent de courant de fuite de terre possible".
- a) **Line voltage must be within the limits of table 2 below.** (Install a "buck-boost transformer" if the line voltage is not between these values.) Circuit breaker switches must be 20 amp minimum on singles and 30 amp on dual.
- b) Local code may require you to provide a quick disconnect (safety switch) for the vacuum unit.
- c) The Eco-Vac is controlled by a 24 volt circuit. For remote switching, provide one 18/3 jacketed cable for the switching on and off each unit. (Dual units need two sets of 18/3 jacketed cable)

TABLE 1

PUMP SIZE	SINGLE	DUAL
EXHAUST VENT (DIA)	2"	2"

TABLE 2

PUMP VOLTAGE	AMPERAGE	MIN. LINE VOLTAGE	MAX. LINE VOLTAGE
230v SINGLE MOTOR	12 AMPS	208v CONSTANT	240v CONSTANT
230v DUAL MOTOR	24 AMPS	208v CONSTANT	240v CONSTANT


INSTALLATION

This dry vacuum unit should only be installed by qualified personnel. Should any questions arise during the installation, call Tech West Technical Support between the hours of 7:00 a.m. to 5:00 p.m. (Pacific Standard Time).

Place the dry vacuum in a clean, dry, well ventilated area, on a solid, level surface. Be sure that adequate ventilation is available and install an exhaust fan. Ambient temperature in the equipment room should be within the temperature range of 40 degrees Fahrenheit minimum to 100 degrees Fahrenheit maximum.

- 1) Check the shipping carton for damage. This could detect damage to the unit which might otherwise be overlooked. Remove cardboard shipping carton.
- 2) Remove the Vacuum from its shipping carton. Inspect the unit for damage.
- 3) Dry vacuums are shipped bolted to a pallet. This pallet is intended for shipping only and should be discarded.
- 4) Inventory your hook-up kit. Check its contents against the inventory sheet included. These items will be used in the remaining steps.
- 5) Install rubber mounting feet on underside of unit.
- 6) Mount the separator tank onto the top of the steel frame with the bolts provided or On size of the unit.
- 7) Connect the suction hose from top of the tank to the vacuum with the flex hose provided.
- 8) Make the necessary exhaust vent connections. (WARNING: Exhaust can be vented with a pvc pipe)
- 9) Connect the main vacuum line. Connect flexible 1 1/4" hose to the side of separator tank.
- 10) Connect remote control 18/3 jacketed cable to the relay panel. Use wire connectors that provide secure mechanical connections.
- 11) Connect line voltage (via safety switch if required by local code). Refer to the wiring diagram.
- 12) Turn on the Vacuum. Check the pump(s) for leaks and the vacuum level following

CONNECTIONS



WEEKLY SERVICING

- 1) Flush the main vacuum lines with **NON-FOAMING** dental vacuum cleaner. Follow the cleanser manufacturer's instructions. Most brands say non-foaming but, in fact, do foam. We recommend Bio-Pure. (Bio-Pure Products 1-888-596-6546)
- 2) Visually inspect Vacuum for water leakage. Ensure that all hoses and water connections are tight.
- 3) Flush the entire vacuum piping system (all operatories) weekly. Use a **NON-FOAMING** cleanser. It is extremely important that the cleaner used cannot and will not foam. Foam will get sucked into the vacuum producer and will cause damage over time. If the Vacuum cannot induce adequate air flow because of a blockage in the vacuum piping system, liquids and solids will not evacuate. Contact Tech West's Technical Support for further details on maintaining your vacuum piping system.

HOW TO SIZE A VACUUM AND AIR SYSTEM

Both the drawing and the size chart are sized to accommodate a vacuum system for 100% use. This is done to produce good vacuum pressures and flows at all times from all operatories. normally, you always use this design for a proper system in the event all six are used simultaneously; You would not have any suction loss due to improperly sized main or branch lines.

Important: do not figure or draw any nitrous or sink evacuation terminations until you have a complete system showing termination to high volume evacuation connections normally found in dental unit junction box.

Additional 3/4" vacuum lines for nitrous oxide scavenge and evacuator sinks can be added without affecting main or branch line sizes.

Step 1)

Count the total number of operatories to be plumbed and select the vacuum line size for either pvc or copper pipe. see the line sizing chart in figure 2

Step 2)

This pipe size you have selected will be the starting line or main line and begins at the equipment location. the vacuum line will use a main line riser assembly as shown in figures 1.

Step 3)

After figuring your main line size, you may select the best location to split your piping lines to best accommodate the operatories. each zone becomes its own system for purposes on sizing the lines properly. if operatories are in a straight line, zone splitting will not be required.

Step 4)

Starting from zone split location, count remaining operatories and look at the sizing chart in figure 2 select correct branch line diameter.

FIGURE 2. VACUUM LINE SIZING CHART		
NUMBER OF OPERATORIES SEE NOTE	VACUUM LINE PIPE DIAMETER	
	PVC sch 40	COPPER TYPE "M"
1	1 1/4"	1"
2	1 1/4"	1"
3	1 1/4"	1 1/4"
4	1 1/2"	1 1/2"
5	1 1/2"	1 1/2"
6	2"	1 1/2"
7	2"	1 1/2"
8	2"	1 1/2"

DO NOT ALLOW ANY PIPE TO BRANCH OFF ANOTHER PIPE BELOW THE CENTERLINE OF THE MAIN OR BRANCH LINE PIPE. SEE FIG. 6 FOR CORRECT BRANCH LINE TAKE OFF.

IMPORTANT

TO PREVENT SUCTION LOSS, DO NOT ALLOW A TRAP TO BE PLUMBED AT ANY LOCATION IN THE SYSTEM EXCEPT MAIN LINE RISER ASSEMBLY (FIG. 1) AND OVERHEAD VERTICAL RISER (FIG. 5).




FIG. 7 MOST COMMON VACUUM PLUMBING ERRORS

THREE POSSIBLE PLUMBING METHODS FROM MAIN OR BRANCH LINE TO TERMINATION IN OPERATORY, N2O, SINK AND JUNCTION BOX.




FIG. 8 N2O AND SINK VACUUM CONNECTIONS

BRANCH LINE TERMINATION TO TWO OPERATORIES




FIG. 10

THIS BRANCH LINE TERMINATION IS SHOWN CORRECTLY. NEVER USE THE INCORRECT EXAMPLE SHOWN AT LEFT FOR VACUUM SYSTEMS.

Hanger supports required every eight feet or to support piping without sags.

Always stub vacuum and air line into wall or floor junction box per manufacturer's template. If 1/2" is required, you may reduce pipe size as close as possible to termination point. If a larger size is required, this change must be made within junction box.

All vacuum piping illustrations and drawings are shown with pvc pipe SCH40 and DWV type fittings. Always use swv fittings. Not available below 1 1/4".

All vacuum piping should grade toward equipment location 1/4" in ten feet.

When installing an overhead system, use the next larger vacuum pump model for best results.

Install trap in main line just before hooking the flexible intake hose connection to pumps. See Fig. 1, Example B.

In an overhead system, the main vacuum line will drop down to the dry-vac location using required pipe size. all overhead systems are sized in the same manner as the system shown here.



Do not run poly flo tubing below slab. always run pipe up above slab, then make poly flo connection.

Fig. 2 line sizing chart shows main vacuum line size diameter for 4, 5 and 6 operatories as 1 1/2" diameter. If 1 1/2" diameter is not available, you may use 2" diameter.



Riser assy. must always be used. See Fig. 1 Example A for riser assy. specifications.


Control panel supply lines should be connected close to equipment room and must always connect vertically.


ELECTRICAL WIRING DIAGRAM



TERMINAL
STRIP (6)








ECO VAC MOTOR BREAKDOWN

No.	Qty.	Description
1.01	1	Cover
1.02	1	Center Section
1.03	1	Housing
1.04	1	Mounting Plate
1.05	4	Plate Mounting Screw
1.06	4	Mounting Plate Washer
1.07	4	Mounting Plate Nut
1.08	1	Stator Support Screw
1.09	1	Stator Support Lock Washer
1.10	2	Stator Support Washer
1.11	1	Stator Support Sleeve
1.12	3	Bearing Cover Screw
1.13	3	Bearing Cover Washer
1.14	3	Bearing Ring Seal
1.15	8	Cover Mounting Screw
1.16	8	Cover Mounting Nut
1.17	4	Motor Mounting Screw
1.18	1	Lifting Ring Nut
1.19	1	Lifting Ring
1.20	2	Blower Cowl
1.21	4	Blower Cowl Screw
2.01	1	Shaft Screw
2.02	1	Shaft Lock Washer
2.03	1	Disc
2.04	1	Bearing
2.05	1	Bearing Cover O-Ring
2.06	1	Bearing Cover
2.07	2	Impeller
2.08	1	Rotary Shaft Seal
2.09	1	Sleeve
2.10	1	Disk
2.11	1	Shaft Seal Ring
2.12	4	Teflon Seal
2.13	4	Retaining Ring
2.14	32	Inner Seal Screw
3.01	1	Motor Rotor
3.02	1	Stator
3.03	2	Motor Terminal Box Gasket
3.04	1	Terminal Box
3.05	1	Cover For Terminal Box
3.06	8	Terminal Box Screw
3.07	1	Terminal Block
3.08	1	Terminal Block Screw
3.09	1	Rear Bearing
3.10	1	End Shield Disk
3.11	1	End Shield
3.12	4	End Shield Screw
3.13	1	External Fan
3.14	1	Fan Cowl
3.15	4	Fan Cowl Screw
3.16	2	Parallel Key
4.01	4	Silencer Gasket
4.02	2	Silencer Insert Filler
4.03	2	Silencer Insert
4.04	2	Silencer Casing
4.05	4	Silencer Screw
4.06	4	Flange Cap
4.07	2	Flange Cap
4.08	2	Flange Filler
4.09	16	Filler



Notes

This image shows a full page of blank, lined paper. It features approximately 28 horizontal black lines spaced evenly across the page, typical of notebook paper. The lines are thin and extend from the left edge to the right edge. There are no margins, text, or other markings on the page.

Notes

[illegible]



TECH WEST INC.

Manufacturers of Dental Vacuum
and Air Systems

2625 N. Argyle Ave. • Fresno, CA 93727
(559) 291-1650 • (800) 428-7139 • FAX (559) 348-9677
www.tech-west.com