

Johnson Lifts Private Limited

NO.40 5TH MAIN ROAD K.S.S.I.D.C INDUSTRIAL ESTATE, 6TH BLOCK RAJAJI NAGAR, BENGALURU PIN: 560010

LAKSHMI KANTH.B.N

JOB NO L-Q7747

-, NO:5093, 4TH CROSS, -
, RAVINDRA NAGAR,
HASSAN, PIN: 573201,

DATE :-Mon Oct 31 2022 14:20:35 GMT+0530 (India Standard Time)

Respected sir,

With ref to our site visit /inspection we have found the following works are pending from your side & the same has been informed to your supervisor / engineer. We request you to complete the below pending work at the earliest to prepare lift shaft for material delivery and lift installation.

S.No	TASK DESCRIPTION	STATUS
1	SMOKE WINDOW TO BE PROVIDED FOR MRL TYPE LIFT AS PER GAD	No
2	LIFT WELL BRICK WORK AND PLASTERING, COMPLETED AS PER GAD.	No
3	LIFT PIT FINISHED AS PER GAD AND WATER PROOFING TO BE DONE	No
4	SCAFFOLDING COMPLETED AS PER THE SKETCH GIVEN BY JOHNSON LIFTS.	No
5	LIFT WELL WHITE WASHING ONE COAT COMPLETED	No
6	STORE ROOM PROVIDED AT GROUND FLOOR WITH LOCKABLE ARRANGEMENT NEAR THE LIFT SHAFT WITH ADEQUATE LIGHTING	No
7	3 PHASE POWER SUPPLY METAL PANNEL BOARD PROVIDED WITH SUITABLE 4 POLE MCB 1 NO. _____ AMPS AND ELCB 1NO _____AMPS .	No
8	TWO INDEPENDENT EARTH TERMINALS (8 GAUGE COPPER / G1 WIRE/GI plate) PROVIDED	No
9	POWER CABLE TO TAKEN OUTSIDE OF THE LIFT SHAFT (NOT APPLICABLE FOR MAHARASHTRA STATE)	No
10	PERMANENT LIFT WELL LIGHTING WITH 5 AMPS 3 PIN SOCKET WITH SWITCH AS PER DRAWING	No
11	TEMPORARY LIGHTING ARRANGEMENT PROVIDED AT THE LIFT SHAFT AREA FOR LIGHTING DURING ERECTION TIME	No
12	TWO NOS. TUBE LIGHT FIXED AT THE HEAD ROOM FOR MRL TYPE LIFTS	No

Remarks :-

1.Lift pit depth 1350mm(4'1/2'). required as per GAD. 2.TOP floor SAP panel cutout to be provide and electric panel also to be fix.3.Emergency window tofix with lockable.4.Lift shaft scaffolding to be done as per our drawing.5.Lift shaft bulkhead light connection to be given as per our GAD.6.3PHASE incoming electric connection given shaft outside only.

Site Engineer Signature

Name :- Lakshmikanth.B.N.

Designation :- Owner