Johnson Lifts Private Limited

PLOT NO.R7/2 & 3, NORTH MAIN ROAD, ANNA NAGAR WESTERN EXTN. CHENNAI PIN: 600101

ROHIT BUILDERS JOB NO L-Q7187

DATE :-Wed Aug 17 2022 16:16:48 GMT+0530 (India Standard Time)

10, RANGAN STREET, T NAGAR, CHENNAI, TAMILNADU, PIN: 600017,

Respected sir,

With ref to our site visit /inspection we have found the following works are pending from your side & the same has been informed to your supervisor / engineer. We request you to complete the below pending work at the earliest to prepare lift shaft for material delivery and lift installation.

| S.No | TASK DESCRIPTION | STATUS |
|------|---|--------|
| 1 | MACHINE ROOM 2 NOS. LOUVER TYPE VENTILATORS WITH GLASS TO BE FIXED AS PER OUT GAD (SIZE 3' - 0" X 2' - 0") | No |
| 2 | MACHINE ROOM STEPS WITH HAND RAIL TO BE PROVIDED (3' - 0" WIDE) | No |
| 3 | LIFT WELL BRICK WORK AND PLASTERING, TO BE COMPLETED AS PER GAD. | No |
| 4 | SCAFFOLDING TO BE COMPLETED AS PER THE SKETCH GIVEN BY JOHNSON LIFTS. | No |
| 5 | LIFT WELL WHITE WASHING ONE COAT TO BE COMPLETED | No |
| 6 | STORE ROOM TO BE PROVIDED PREFERABLY AT GROUND FLOOR WITH LOCKABLE ARRANGEMENT NEAR THE LIFT SHAFT WITH ADEQUATE LIGHTING | No |
| 7 | TEMPORARY SINGLE PHASE POWER SUPPLY, 5 AMPS, 3 PIN PLUG WITH SWITCH TO BE PROVIDED NEAR THE LIFT SHAFT | No |
| 8 | MACHINE ROOM 3 PHASE POWER SUPPLY METAL PANNEL BOARD TO BE PROVIDED WITH SUITABLE 4 POLE MCB 1 NO. AMPS AND ELCB 1NOAMPS . | No |
| 9 | MACHINE ROOM SINGLE PHASE POWER SUPPLY TO BE PROVIDED WITH SUITABLE 2 POLE MCB (3 NOS.) FOR SHAFT, MACHINE ROOM AND LIFT LIGHTING | No |
| 10 | TWO INDEPENDENT EARTH TERMINALS (8 GAUGE COPPER / G1 WIRE) TO BE PROVIDED TO THE MACINE ROOM. | No |

Remarks :-

trail job

Site Engineer Signature

Name :- Mr.k.swathii

Designation :- engineer