

Johnson Lifts Private Limited

PLOT NO.R7/2 & 3, NORTH MAIN ROAD, ANNA NAGAR WESTERN EXTN. CHENNAI PIN: 600101

ROHIT BUILDERS

JOB NO 61c561a83c5cfc7d49dfa1fc

10, RANGAN STREET, T  
NAGAR, CHENNAI,  
TAMILNADU, PIN:  
600017,

DATE :-Thu Apr 21 2022 15:49:45 GMT+0530 (India Standard Time)

Respected sir,

With ref to our site visit /inspection we are found following works are pending from your side same was inform to your supervisor / engineer .we are requesting you to complete the pending work at the earliest to prepare lift shaft for material delivery and lift installation .

S.No	TASK DESCRIPTION	STATUS
1	MACHINE ROOM ROOF SLAB TO BE PROVIDED	No
2	MACHINE ROOM WHITE WASHING TO BE COMPLETED	No
3	MACHINE ROOM DOOR (3' - 0" WIDE) TO BE FIXED, OPEN OUTWARDS.	No
4	MACHINE ROOM 2 NOS. LOUVER TYPE VENTILATORS WITH GLASS TO BE FIXED AS PER OUT GAD (SIZE 3' - 0" X 2' - 0")	No
5	MACHINE ROOM STEPS WITH HAND RAIL TO BE PROVIDED (3' - 0" WIDE)	No
6	MACHINE ROOM FLOORING TO BE COMPLETED	No
7	SMOKE WINDOW TO BE PROVIDED FOR MRL TYPE LIFT AS PER GAD	No
8	LIFT WELL BRICK WORK AND PLASTERING, TO BE COMPLETED AS PER GAD.	No
9	LIFT WELL ENTRANCE WALL BRICK WORKS, LINTAL WORKS & PLASTERING AT ALL FLOOR LANDINGS TO BE COMPLETED ONLY FOR POD LIFTS/MS SWING DOOR LIFTS	No
10	MACHINE ROOM 3 PHASE POWER SUPPLY METAL PANNEL BOARD TO BE PROVIDED WITH SUITABLE 4 POLE MCB 1 NO. _____ AMPS AND ELCB 1NO _____AMPS .	No
11	Automation Data Rev Automation Data Rev .XLSX 100% 10 B55 MACHINE ROOM SINGLE PHASE POWER SUPPLY TO BE PROVIDED WITH SUITABLE 2 POLE MCB (3 NOS.) FOR SHAFT, MACHINE ROOM AND LIFT LIGHTING To enable screen reader support, press ⌘+Option+Z To learn about keyboard shortcuts, press ⌘/slash MACHINE ROOM SINGLE PHASE POWER SUPPLY TO BE PROVIDED WITH SUITABLE 2 POLE MCB (3 NOS.) FOR SHAFT, MACHINE ROOM AND LIFT LIGHTING Turn on screen reader support	No
12	TWO INDEPENDENT EARTH TERMINALS (8 GAUGE COPPER / G1 WIRE) TO BE PROVIDED TO THE MACINE ROOM.	No
13	POWER CABLE TO TAKEN OUTSIDE OF THE LIFT SHAFT (NOT APPLICABLE FOR MAHARASHTRA STATE)	No
14	PERMANENT LIFT WELL LIGHTING WITH 5 AMPS 3 PIN PLUG WITH SWITCH AS PER DRAWING	No
15	TEMPORARY LIGHTING ARRANGEMENT TO BE PROVIDED AT THE LIFT SHAFT AREA FOR LIGHTING DURING ERECTION TIME	No

Remarks :-

attending by swathi

Site Engineer Signature

Swathi

Name :- raman

Designation :- superior