

SAFE WORK METHOD STATEMENT (SWMS)

DOCUMENT CONTROL	
SWMS_ID	SWMS-002
SWMS_Title	Burner Clean
SWMS_Version	1.1
SWMS_Type	☐ Core SWMS ☒ Routine Task SWMS ☐ Non-Routine Task SWMS
Status	☐ Draft ☒ Current ☐ Superseded
Authorised_By	Chris Foster
Authorised_Date	25/06/2026
Review_Date	25/07/2027
Review_Period_Months	12
Review_Trigger	☒ Initial Issue ☐ Incident ☐ Legislative Change ☐ Procedure Change ☐ Equipment Change ☐ Risk Assessment Review ☒ Scheduled Review
Revision_Summary	Scheduled Review

REVISION HISTORY

Version	Date	Change Summary	Authorised By
1.0	20/01/2024	Initial Issue	Chris Foster
1.1	25/06/2026	Scheduled Review	Chris Foster

SWMS ID: SWMS-0002		SWMS Title: Burner Clean	
Prepared By: Chris Foster		Date: 25/06/2026	
Business Name: Tuan Biomass Albioma			
Description of Task: Cleaning Glass and slag build up inside burner remove debris and inspect			
Reason for analysis: ☒ New task/plant ☒ High Risk Task ☐ Change ☐ Regular review ☐ Post-Incident ☐ Contractor (to complete) Task ☐ Non-Routine Task ☐ Maintenance/Repair ☐			
Other (specify):			
SWMS Team Names: 1. Chris Foster		2. David Knight	
3.		4.	
5.		6.	
Permits Required: (circle) Confined Space ☒ Isolation ☒ Hot Work ☐		PPE Requirements:              Other: Atmosphere Tester	

CONTROLLED MASTER DOCUMENT

Doc Id: SWMS – 001- 2024-v2.0	Page 1 of 4
Doc Owner: Tuan Safety and Compliance Manager	Issue Date: 20 November-2024
Last Review: 24-Jun-2026	Version No: 001

SAFE WORK METHOD STATEMENT (SWMS)

Potential Environment Hazards	Fire/Emergency Response Equipment
☒ Noise / vibration ☒ Air pollution – dust / smoke / fume ☒ Spills to ground ☒ Spills to water / drains / waterways ☐ Soil erosion / contamination ☒ Hazards to flora & fauna ☒ Waste generation & disposal ☒ Hazardous chemicals / substances ☐ Vegetation / bushfire risk ☐ Other: _____	☒ Fire extinguisher — Location: Main shed wall ☒ Fire hose / hydrant — Location: Walking Floor, Shavings silo, inside shed ☒ First aid kit — Location: Smoko Room ☒ Spill kit — Location: Inside the North Entry door ☒ Emergency eyewash / shower — Location: Outside the workshop ☒ Emergency assembly point — Location: ☒ Communication method: ☐ Radio ☐ Phone ☐ Verbal ☒ Emergency contact No: 0439 013 224
Hazards Identified	
☒ Electricity ☒ Confined Space ☐ Stored Energy ☒ Extreme Temperatures ☒ Dust and or fume ☒ Hazardous Manual Tasks ☐ Psychological ☐ Traffic/Mobile Plant ☐ Ignition Sources ☒ Lighting ☒ Machinery & Equipment ☐ Person/Object Falling ☐ Pressure (air, water, gas) ☒ Object Falling ☐ Hazardous Chemicals ☐ Hot Work ☐ Other workers/people	
Other Comments:	

REQUIRED CORE SWMS

List the Core SWMS that also apply to this task. Linked Core SWMS must be read and signed on through the online SWMS Register together with this SWMS.

Applies	Core SWMS	Linked SWMS_ID
☒	Isolation and LOTO	SWMS-026
☐	Hot Work	
☒	Confined Space Entry	SWMS-024
☐	Working at Heights	
☐	Crane and Lifting Operations	
☐	Working on un-isolated plant	

CRITICAL CONTROLS

The following critical controls must be in place and verified before work starts.

#	Critical Control (must be in place before work starts)	In place
1	Confined Space Entry Permit issued, signed and valid for the burner; entry register maintained at the access point. Entry by trained, authorised personnel only.	☒
2	All energy sources isolated and locked out under the LOTO permit (electrical, fuel-feed fan, mechanical, stored/thermal) and verified at zero energy before entry. (Linked: SWMS-026, SWMS-024)	☒
3	Burner cooled and confirmed below safe working temperature by measurement before entry; hot surfaces and residual slag verified safe to approach.	☒
4	Atmosphere tested before entry and continuously monitored during occupancy — O ₂ 19.5–23.5%, LEL <5%, CO and other contaminants below WES. Entry prohibited and work stops if any reading is out of range.	☒
5	Forced/mechanical ventilation (ID fan and/or combustion fans) running before and throughout entry to control dust, fume and combustion residues.	☒
6	Trained standby person stationed at the entry point with continuous communication to entrants; written confined-space rescue plan displayed at entry and rescue equipment in place before entry begins.	☐

If a critical control cannot be implemented, work must stop and the SWMS must be reviewed before proceeding.

CONTROLLED MASTER DOCUMENT			
Doc Id: SWMS – 001- 2024-v2.0		Page 2 of 4	
Doc Owner: Tuan Safety and Compliance Manager		Issue Date: 20 November-2024	
Last Review: 24-Jun-2026		Version No: 001	

SAFE WORK METHOD STATEMENT (SWMS)

Key Steps in Logical Order		Hazards/Risks to Workers or Public	Risk Score	Control Measures	Residual Risk Score
1	Open doors, remove bricks, and run combustion fans to cool burner 24 hours before scheduled clean	- Exposure to heat - Risk of burns from residual heat - Manual handling injuries - Dust and ash particulates	Low	- Allow sufficient cooling before opening doors. - Wear gloves - Dust masks provided for workers.	Low
2	Gain access to burner with all tools needed to clean the burner.	- Strains from awkward manual handling lifting tools through tight access. - Risk of burns from residual heat - Confined space - injury or medical emergency in burner	Moderate	- Team lifting pass heavy items through the doors. - Allow sufficient cooling before entering. - Confined space permit. - Atmosphere tester. - Stand-by person - Isolate the fuel feed fan. - written emergency plan clearly displayed at the entrance to the confined space.	Low
2	Jackhammer and remove build up and debris from burner	- Manual handling injuries - Vibration-related injuries - Flying debris - Trip hazards - Dust and ash particulates - Risk of burns from residual heat - Cuts or lacerations from sharp fragments of glass.	High	- Rotate jobs every 15-20 mins. - Impact-resistant safety glasses face shield or goggles provided. - Maintain a clean and organised burner floor removing debris regularly. - Coveralls & dust masks - Run ID fan and/or combustion fans to ventilate burner. - Hard Hat - Long shirt & pants. - Gloves	Low
4	Inspect burner	-Unauthorized entry to confined space by person/s not listed on permit.	Low	- Confined space train provided to all workers entering confined spaces. - Confined space permit. - Confined space sign at entry with authorised workers names displayed.	Low
5	Remove all tools	-Manual handling strains lifting through tight access. - Dust and ash particulates	Mod	- Team lifting pass heavy items through the doors. - Keep all PPE on until job complete.	Low
6	Close the doors	- Heat leaks due to Improper stacking of bricks - Pinch points when stacking bricks - Dust inhalation	Low	- Ensure proper alignment of bricks inside burner door. - Gloves - Dust masks	Low

Add additional job steps, hazards and controls as required

All relevant workers must be consulted during the development and review of this SWMS and made aware of the control measures and all required permits. Worker consultation and sign-on are recorded through the online SWMS Register.

CONTROLLED MASTER DOCUMENT

Doc Id: SWMS – 001- 2024-v2.0

Page **3** of **4**

Doc Owner: Tuan Safety and Compliance Manager

Issue Date: 20 November-2024

Last Review: 24-Jun-2026

Version No: 001

SAFE WORK METHOD STATEMENT (SWMS)**ONLINE SWMS MANAGEMENT**

Worker sign-on is completed through the online SWMS Register.

Workers are required to read and sign onto this SWMS once per review period, or sooner if the SWMS is revised, superseded, or changed due to an incident, equipment change, procedure change, legislative change, or risk assessment review.

Before each task commences, the team or person in control of the work must review the SWMS through the online task review system and confirm whether anything has changed from the approved SWMS.

If no changes are identified, the task may proceed once all workers are confirmed as current against the required SWMS.

If changes are identified, the changes and additional controls must be recorded in the online Task Record before work proceeds. Supervisor review is required where the change affects the work method, plant, equipment, location, hazards, permit requirements, or critical controls.

System of record

This Word document is the controlled master SWMS. The PDF is the worker-view copy. The HTML tablet page is used to view the SWMS and complete the task review.

Worker sign-off is stored in Worker_SWMS_Register. Daily task reviews are stored in Task_Records. Review dates and version status are controlled in SWMS_Library.

AUTHORISATION**Approved by:** Chris Foster**Position:** Safety and Compliance Manager**Approval Date:** 25/06/2026**CONTROLLED MASTER DOCUMENT****Doc Id:** SWMS – 001- 2024-v2.0Page **4** of **4****Doc Owner:** Tuan Safety and Compliance Manager**Issue Date:** 20 November-2024**Last Review:** 24-Jun-2026**Version No:** 001