

SAFE WORK METHOD STATEMENT (SWMS)

DOCUMENT CONTROL	
SWMS_ID	SWMS-003
SWMS_Title	Dust Blower Bag Change
SWMS_Version	1.0
SWMS_Type	☐ Core SWMS ☒ Routine Task SWMS ☒ Non-Routine Task SWMS
Status	☐ Draft ☒ Current ☒ Superseded
Authorised_By	Chris Foster
Authorised_Date	25/06/2026
Review_Date	25/06/2026
Review_Period_Months	12
Review_Trigger	☒ Initial Issue ☒ Incident ☐ Legislative Change ☐ Procedure Change ☐ Equipment Change ☐ Risk Assessment Review ☐ Scheduled Review

REVISION HISTORY

Version	Date	Change Summary	Authorised By
1.0	15/12/2025	Initial Issue	Chris Foster
1.1	25/06/2026	Scheduled Review	Chris Foster

SWMS ID: SWMS-003		SWMS Title: Dust Blower Bag Change	
Prepared By: Chris Foster		Date: 15/12/2025	
Business Name: Tuan Biomass Albioma			
Description of Task: Replace bag house filters in dust collector. Work location: Surge bin.			
Reason for analysis: ☐ New task/plant ☐ High Risk Task ☐ Change ☐ Regular review ☐ Post-Incident ☐ Contractor (to complete) Task ☐ Non-Routine Task ☒ Maintenance/Repair ☒			
Other (specify):			
SWMS Team Names: 1. David Knight		2. Chris Foster	3.
4.		5.	6.
Permits Required: (circle) Confined Space ☒ Isolation ☒ Hot Work ☐		PPE Requirements: (circle)             Other:	
Potential Environment Hazards		Fire/Emergency Response Equipment	

CONTROLLED MASTER DOCUMENT

Doc Id: SWMS – 003- 2025-v2.0	Page 1 of 3
Doc Owner: Tuan Safety and Compliance Manager	Issue Date: 20 November-2024
Last Review: 24-Jun-2026	Version No: 001

SAFE WORK METHOD STATEMENT (SWMS)

☐ Noise / vibration ☒ Air pollution – dust / smoke / fume ☒ Spills to ground ☒ Spills to water / drains / waterways ☐ Soil erosion / contamination ☐ Hazards to flora & fauna ☒ Waste generation & disposal ☐ Hazardous chemicals / substances ☐ Vegetation / bushfire risk ☐ Other: _____	☒ Fire extinguisher — Location: Main shed wall ☒ Fire hose / hydrant — Location: Walking Floor, Shavings silo, inside shed ☒ First aid kit — Location: Smoko Room ☒ Spill kit — Location: Inside the North Entry door ☒ Emergency eyewash / shower — Location: Outside the workshop ☒ Emergency assembly point — Location: ☒ Communication method: ☐ Radio ☐ Phone ☐ Verbal ☒ Emergency contact No: 0439 013 224
---	--

Hazards Identified

- ☒ Electricity
 ☒ Confined Space
 ☐ Stored Energy
 ☒ Extreme Temperatures
 ☒ Dust and or fume
 ☒ Hazardous Manual Tasks
☐ Psychological
 ☒ Traffic/Mobile Plant
 ☐ Ignition Sources
 ☐ Lighting
 ☒ Machinery & Equipment
 ☒ Person/Object Falling
☐ Pressure (air, water, gas)
 ☒ Object Falling
 ☐ Hazardous Chemicals
 ☐ Hot Work
 ☐ Other workers/people

Other Comments:

REQUIRED CORE SWMS

List the Core SWMS that also apply to this task. Linked Core SWMS must be read and signed on through the online SWMS Register together with this SWMS.

Applies	Core SWMS	Linked SWMS_ID
☐	Isolation and LOTO	SWMS-026
☐	Hot Work	SWMS-005
☐	Confined Space Entry	SWMS-024
☐	Working at Heights	SWMS-025
☐	Crane and Lifting Operations	
☐	Working on isolated plant	

CRITICAL CONTROLS

The following critical controls must be in place and verified before work starts.

#	Critical Control (must be in place before work starts)
1	Isolation of HP blower, dust collection blower and air cleaning cycle completed and verified (LOTO applied and tested for zero energy).
2	Inspection hatch inspection completed prior to opening – area below clear of personnel.
3	Respiratory protection (P2 minimum) and safety goggles or glasses worn by all personnel involved in bag removal.
4	Walkways and access platforms clear of dust and debris before access.
5	Three points of contact maintained at all times on ladders and elevated platforms.
6	All workers below exclusion zone cleared before dropping or lowering removed filters.

If a critical control cannot be implemented, work must stop and the SWMS must be reviewed before proceeding.

CONTROLLED MASTER DOCUMENT

Doc Id: SWMS – 003- 2025-v2.0	Page 2 of 3
Doc Owner: Tuan Safety and Compliance Manager	Issue Date: 20 November-2024
Last Review: 24-Jun-2026	Version No: 001

SAFE WORK METHOD STATEMENT (SWMS)

Key Steps in Logical Order		Hazards/Risks to Workers or Public	Risk Score	Control Measures	Residual Risk Score
1	Isolate equipment – complete isolation request form, isolate HP blower, isolate dust collection blower, isolate air cleaning cycle and wait until final air cycle completes. Apply LOTO and test for zero energy.	Accidental machine start-up. Residual air in cleaning cycle.	Moderate	Complete isolation request form. Isolate HP blower, dust collection blower, and air cleaning cycle. Wait for final air cycle to complete. Apply LOTO and test for zero energy before opening any access.	Low
2	Open inspection hatch on top of bag house to gain access to bag filters. Access via fixed ladder and platforms only.	Falls from height. Slips and trips on walkways. Dropped objects.	Moderate	Access via fixed ladder and platforms only. Keep walkways clear of dust and debris. Maintain three points of contact. Do not place loose tools on handrails or grating.	Low
3	Push filters into cyclone, then remove filters through access hatch one at a time.	Respiratory irritation or eye injury from residual dust and airborne particles. Pinch points.	Moderate	Wear respiratory protection and safety goggles. Keep hands clear of pinch points. Use controlled steady force when pushing filters. Remove filters one at a time – ensure workers below are clear. Do not overreach.	Low
4	Close access hatch, then de-isolate equipment.	Pinch points. Manual handling strain. Unauthorised restart. Communication failure.	Moderate	Wear PPE (gloves). Use correct manual handling techniques and appropriate tools. Follow LOTO procedure for de-isolation. Confirm with senior operator prior to restart.	Low

Add additional job steps, hazards and controls as required

All relevant workers must be consulted during the development and review of this SWMS and made aware of the control measures and all required permits. Worker consultation and sign-on are recorded through the online SWMS Register.

ONLINE SWMS MANAGEMENT

Worker sign-on is completed through the online SWMS Register.

Workers are required to read and sign onto this SWMS once per review period, or sooner if the SWMS is revised, superseded, or changed due to an incident, equipment change, procedure change, legislative change, or risk assessment review.

Before each task commences, the team or person in control of the work must review the SWMS through the online task review system and confirm whether anything has changed from the approved SWMS.

If no changes are identified, the task may proceed once all workers are confirmed as current against the required SWMS.

If changes are identified, the changes and additional controls must be recorded in the online Task Record before work proceeds.

Supervisor review is required where the change affects the work method, plant, equipment, location, hazards, permit requirements, or critical controls.

System of record

This Word document is the controlled master SWMS. The PDF is the worker-view copy. The HTML tablet page is used to view the SWMS and complete the task review.

Worker sign-off is stored in Worker_SWMS_Register. Daily task reviews are stored in Task_Records. Review dates and version status are controlled in SWMS_Library.

AUTHORISATION		
Approved by: Chris Foster	Position: Safety and Compliance Manager	Approval Date: 15/12/2025

CONTROLLED MASTER DOCUMENT	
Doc Id: SWMS – 003- 2025-v2.0	Page 3 of 3
Doc Owner: Tuan Safety and Compliance Manager	Issue Date: 20 November-2024
Last Review: 24-Jun-2026	Version No: 001