



8/27 Allgas Street
Slacks Creek QLD 4127
Tel. 07 3155 4225
qpower.com.au
ABN 82 067 507 591
Licence # 69807

PLEASE PAY BY	AMOUNT	INVOICE DATE
23/09/2026	\$691.63	09/09/2026

Invoicing
Logan City Council
PO Box 3226
Logan City DC QLD 4114

TAX INVOICE NO. 15267

Site: Darlington Parklands
Site Address: Huggins Avenue
Yarrabilba QLD
Order No.: 717370 + CR3941881

Description

Work Requested:

Attend site to investigate and repair shelter shed lights not working.
PK000441
Shelter shed lights are not working. Repairing these lights will assist with anti-social activity within the park.

Ordered By:

Aisha Wilson

Works Completed:

Inspected shelter shed lights and confirmed they are fed from DB1 inside the pump house, with the PE cell located on the external wall behind DB1.
Located J-bell inside pit for pathway lights. Found 20A circuit breaker faulty and replaced with new 20A Hager circuit breaker.
Tested cabling and confirmed cabling is working correctly.
Confirmed 3 x shelter lights are not working, with the remaining working light in poor condition and likely to fail in the near future.
Found existing T5 fluorescent fittings have failed and have ant infestation inside. Recommend replacing with LED fittings.
Existing fitting measurements: 1200mm L x 60mm W x 100mm D.
Also assessed associated box/conduit rectification works. Mud map completed and pole number included in photos.
Unable to fully inspect inside box, so allow for possible damaged components. Replacement bracket may also be required.

Material Used:

- 1 x 20A Hager circuit breaker

Updated Client:

Heath updated.

Follow Up Required:

Quote required to replace shelter shed lights with LED fittings and complete associated box/conduit rectification works.



8/27 Allgas Street
Slacks Creek QLD 4127
Tel. 07 3155 4225
qpower.com.au
ABN 82 067 507 591
Licence # 69807

PLEASE PAY BY

AMOUNT

INVOICE DATE

23/09/2026

\$691.63

09/09/2026

TAX INVOICE NO. 15267

Quote Required:

Yes.

Mud Map Completed:

Yes — mud map completed and pole number included in photos.

Material Required:

- Replacement LED fittings to suit 1200mm existing locations
- 1 x 25mm 2-way J box
- 1m x 25mm corrugated conduit
- 500mm stainless strapping
- Replacement bracket if required
- Black heat shrink
- Allow for possible damaged components inside box
- Fixings and sundries

Plant Required:

- EWP may be required
- Box height approximately 3.5m / 12ft
- Platform ladder may be suitable depending on available height
- Cable locator — Nil

Site Access Constraints or Requirements:

- Traffic control — No
- 4WD — No
- EWP access available through P1 removable bollards via park off Darlington Drive if required

Extra Details / Site Concerns:

Access to lights is tight, so allow additional time to fit new lights to purlins.
Unable to fully inspect inside box during attendance.

Service - Do and Charge

Part #	Item	Quantity	Unit Price	GST	Total
	Electrician (LCC)	3.00	\$120.00	10%	\$360.00
	Apprentice	3.00	\$65.00	10%	\$195.00
HAGADC916T	RCBO 6KA 16A 30MA 1P+N 1MOD D/MTG C-CVE TYPE-A	1.00	\$59.75	10%	\$59.75
	Consumables	1.00	\$14.00	10%	\$14.00
Sub-Total ex GST					\$628.75
GST					\$62.88



8/27 Allgas Street
Slacks Creek QLD 4127
Tel. 07 3155 4225
qpower.com.au
ABN 82 067 507 591
Licence # 69807

PLEASE PAY BY	AMOUNT	INVOICE DATE
23/09/2026	\$691.63	09/09/2026

TAX INVOICE NO. 15267

Service - Do and Charge

Part #	Item	Quantity	Unit Price	GST	Total
				Total	\$691.63

Sub-Total ex GST	\$628.75
GST	\$62.88
Total inc GST	\$691.63
Amount Applied	\$0.00
Balance Due	\$691.63

Major credit cards are accepted however a 2.2% surcharge will apply.
To avoid surcharge please pay via Direct Deposit.

How To Pay

INVOICE NO. 15267



Credit Card (MasterCard or Visa)

Pay Online [PAY NOW](#)

Please call 07 3155 4225 to pay over the phone.

Credit Card No.

Card Holder's Name: CCV:

Expiry Date: / Signature:



Direct Deposit

Bank Suncorp
Acc. Name Q Power
BSB 484-799
Acc. No. 611134396