

First Notice of Loss (FNOL)

Commercial Property — Water Damage

Claim Details

Claim Number	CL-8821
Policy Number	POL-2021-44821
Claimant	Meridian Properties LLC
Incident Date	April 12, 2026 · 03:20 ET
Reported	April 12, 2026 · 05:40 ET
Location	318 West Lincoln Ave, Suite 12, Cincinnati OH
Incident Type	Interior water damage (supply-line burst)
Claim Value	\$142,000 (preliminary)
Deductible	\$5,000
Policy Status	Active · no prior claims in 24 months

Narrative

At approximately 03:20 ET on April 12, a 1-inch cold-water supply line on the second floor burst at a soldered joint above suite 12. Water discharged for an estimated 90 minutes before the building engineer was able to shut off the main. Approx. 1,200 sq ft of drywall, carpet, and furniture across four rooms sustained damage. Restoration company ServiceMaster dispatched same-day for water extraction and drying.

Attachments

- First-responder photos (pp. 3–7)
- Moisture readings spreadsheet (p. 8)
- ServiceMaster estimate (\$87,400 mitigation + \$54,600 reconstruction)