

Work Package · WO-2026-00871

Reactor Coolant Pump Bearing Inspection (PM-7B) · P-3A

Work Order ID	WO-2026-00871	Status	CLOSED
Equipment ID	P-3A	System	RCS (Reactor Coolant)
Type	Preventive (PM-7B)	Procedure	0PMP-RCS-7B Rev 2
Opened	2026-03-18 08:00 CST	Closed	2026-03-18 14:30 CST
Lead Engineer	Diane Okafor (EMP-1042)	Hours Charged	6.5 hr
Technicians	Marcus Holloway (EMP-2117), Jamal Greene (EMP-2243)		
Regulatory Basis	TS 3.4.5 / SR 3.4.5.1	NRC Reportable	No

1.0 Scope of Work

Scheduled inspection of P-3A reactor coolant pump thrust and journal bearings per procedure 0PMP-RCS-7B (Rev 2). Includes vibration baseline, bearing oil sample collection, and seal-cavity visual inspection.

2.0 Pre-Job Conditions

Unit 1 in MODE 5 (refueling outage). RCP-3A breaker open and tagged per OSHA 1910.147. Two-person LOTO verification documented in Section 7.0.

3.0 Steps Performed

3.1	Verify LOTO applied + RCP-3A breaker open	✓ Verified by Holloway 08:14
3.2	Remove upper bearing housing access cover	✓ Holloway 08:42
3.3	Visual inspection of thrust bearing (acceptance: no scoring)	✓ Pass — Greene 09:08
3.4	Vibration baseline data collection (axial + radial)	✓ 0.18 in/s axial — Okafor 10:15
3.5	Bearing oil sample collection (3 × 50ml)	✓ Sample ID: BL-2026-0318-P3A-1
3.6	Seal-cavity visual inspection	✓ Dry — no leak signature
3.7	Reinstall bearing housing cover, torque to 95 ft-lbs	✓ Torqued + verified
3.8	Remove LOTO, restore RCP-3A breaker	✓ 13:45 — Holloway
3.9	Post-maintenance functional test (50% rated speed × 30 min)	✓ Pass — vibration 0.21 in/s

4.0 Acceptance Criteria

Per 0PMP-RCS-7B Section 4.0: bearing axial vibration ≤ 0.20 in/s post-maintenance (measured: 0.21 in/s — within tolerance per Engineering Disposition #ED-2026-014). Thrust play 0.020 ± 0.005 in (measured: 0.022 in — pass).

5.0 Findings

No abnormal indications. Bearing surface shows expected wear pattern consistent with 730-day service interval. No corrective action required at this time. Next PM-7B due 2027-06-17 per pm_schedule.

6.0 Sign-Offs

Role	Name	Employee ID	Date / Time
Lead Engineer	Diane Okafor	EMP-1042	2026-03-18 14:30
Technician	Marcus Holloway	EMP-2117	2026-03-18 14:25
Technician	Jamal Greene	EMP-2243	2026-03-18 14:25
Operations Rev.	Sarah Mendez	EMP-1188	2026-03-18 15:02
QA Verification	Tony Garcia	EMP-0871	2026-03-18 16:14