



NATIONAL WATER & SEWERAGE CORPORATION
CENTRAL LABORATORY-BUGOLOBI
P.O BOX 7053 KAMPALA
CERTIFICATE OF ANALYSIS

Client: New Sewage Plant Bugolobi
Address:
Date Sample Received: 05/07/2019
Sample Description: Pumping station
Sampled By: Client's Staff
Sample Number : 3317/2019/C/B

Document No: NWSC/WQ/QF/21.2A
Invoice Number:

Parameters	Units	Test Results	Test Method	National Standards for Waste Water
pH (Physical-Chemical)	--	6.84	APHA3000	
Total Phosphorous (TP)	mg/L	11.773	APHA- 4500-H+ B	
Total Suspended Solids (TSS)	mg/L	167	APHA-2540B	

Remarks:

The Waste water Sample showed complying physio chemical characteristics with exception of TSS and TP as compared to the National Standard for effluent

AUTHORISED BY: Manager Central Laboratory Services.....
APPROVED BY: Senior Manager - Water Quality Management Department



*** The NWSC certificate of analysis by no means continues to permit to any person or company undertaking to conduct business. This report reflects results of the sample as received at the laboratory premises.