

## **NATIONAL WATER & SEWERAGE CORPORATION CENTRAL LABORATORY-BUGOLOBI** P.O BOX 7053 KAMPALA **CERTIFICATE OF ANALYSIS**

**Client: Central Stores** Document No: NWSC/WQ/QF/21.2A

Address: **Invoice No:** 

Date Sample Received: 02/07/2019

Sample Description: CQ-PAC 01/Poly+Cat HB, P8T04/14618, Polyaluminium chloride

Sampled By: Client's Staff Sample Number: 3240/2019/C

Parameters	Units	Test Results	Test Method	National Standards for Bulk Chemical
Chromium	mg/L	3.347	APHA3000	
Chemical Strength	%	25.6	APHA3000	
Specific Gravity		1.34	APHA3000	
PH Correction	53	3.25	APHA3000	
Boiling Point	С	96	APHA3000	

Remarks:

Chemistry: The PACL sample meets NWSC specifications

**AUTHORISED BY:** Manager Central Labaratory Services.....

**APPROVED BY:** Senior Manager - Water Quality Management Department .....



\*\*\* The NWSC certificate of analysis by no means continues to permit to any person or company undertaking to conduct business. This report reflects results of the sample as received at the labaratory premises.