Vegetated Practices: bioretention, rain gardens, bioswales, filter strips, living wall, buffers/shoreline, constructed wetlands, infiltration w/ vegetation. NOTE: Shaded cells to be used for BMP verification

Date of Inspection:_____ **Project/BMP Name:**_____ **Plan/BMP # if applicable:**_____

Type of Inspection: ☐ **Verification 1st Inspection for Permit Cycle** ☐ **Verification Re-Inspection To Confirm Corrective Actions**

BMP Type: ☐ **Stormwater Retrofit** ☐ **New LID Practice** ☐ **Old Stormwater Practice** ☐ **Homeowner BMP**

Date BMP Placed into Service:_____ **Site Address:**_____

_____

Verification Inspector:_____ **Inspector Credential(s):**_____

Photo #s Taken at Site:_____ **Is BMP Still Present?** ☐ **YES** ☐ **NO**

Component:	***Check For:***	***Observations:***	***VERIFICATION***
Drainage Area	□ Erosion □ Sediment/Grit/Dirt □ Stockpiles: □ Bare soil □ Chemicals, oil, etc.: □ Other:		□ **Drainage area conforms to plan?** **If different from plan, note how it is different:**
Inlets to Practices: □ Pipes □ Curb cuts □ Sheetflow □ Other:	□ Obstruction □ Erosion □ Structural/safety issues □ Other		

Component:	*Check For:*	*Observations:*	*VERIFICATION*
Pre-Treatment: □ Forebay □ Grass filter strip □ Grass channel □ Stone pad □ Other: □ None	□ Full of sediment; needs clean-out □ Erosion □ Holding water □ Flow by-passes pre-treatment □ Other		
BMP Surface Area: □ Vegetation □ Mulch □ Other:	□ Appears undersized □ Ponding depth too shallow □ Ponding depth too deep □ Not level; ponding not even across surface □ Sink holes □ Sediment caked on surface □ Standing water □ Trash □ Erosion		□ **Surface area conforms to plan?** **If different from plan, note how it is different:** □ **Ponding depth conforms to plan?** **If different from plan, note how it is different:**
Soil Media: □ Bioretention or Rain Garden mix □ Sand □ Other:	□ Too much clay or wrong soil type; not permeable enough □ Too shallow □ Other:		□ **Soil media appears to conform to plan?** **If different from plan, note how it is different:**
Side Slopes	□ Erosion □ Unstable □ Other:		
Vegetation: □ Trees □ Shrubs □ Herbaceous □ Other:	□ % surface area covered with vegetation: □ Many bare spots □ Dead/diseased/unhealthy plants □ Overgrown □ Invasives □ Too much mulch □ Other:		□ **Vegetation generally conforms to plan OR vegetative cover is adequate?** **If different from plan, note how it is different:**

Component:	***Check For:***	***Observations:***	***VERIFICATION***
Outlets: □ Underdrain(s) □ Overflow structure @ ponding depth □ Other	□ Obstruction/clogging □ By-passing or short-circuiting treatment □ Erosion □ Structural problem □ Other:		
Other			
Issues to Refer to Higher Authority:			
VERIFICATION	☐ **BMP is functioning properly and as designed for pollutant removal.** ☐ **BMP requires corrective or preventative maintenance or rehabilitation to maintain its function for pollutant removal. Actions to be completed within one year:** ☐ **BMP recommended to be downgraded for pollutant removal.**		

Permeable Pavement NOTE: Shaded cells to be used for BMP verification

Date of Inspection:_____ **Project/BMP Name:**_____ **Plan/BMP # if applicable:**_____

Type of Inspection: ☐ **Verification 1st Inspection for Permit Cycle** ☐ **Verification Re-Inspection To Confirm Corrective Actions**

BMP Type: ☐ **Stormwater Retrofit** ☐ **New LID Practice** ☐ **Old Stormwater Practice** ☐ **Homeowner BMP**

Date BMP Placed into Service:_____ **Site Address:**_____

_____

Verification Inspector:_____ **Inspector Credential(s):**_____

Photo #s Taken at Site:_____ **Is BMP Still Present?** ☐ **YES** ☐ **NO**

Component:	***Check For:***	***Observations:***	***VERIFICATION***
Drainage Area	□ Erosion □ Sediment/Grit/Dirt □ Stockpiles: □ Bare soil □ Chemicals, oil, etc.: □ Other: □ Approximate ratio of "run-on" area to permeable: □ Asphalt □ Turf/Landscaped areas		□ **Drainage area conforms to plan?** **If different from plan, note how it is different:**
Pre-Treatment for run-on areas: □ Gravel/stone diaphragm □ Other □ None	□ Full of sediment; needs clean-out □ Erosion □ Holding water □ Flow by-passes pre-treatment □ Other:		

Permeable Surface: □ PICP □ Grid pavers □ Permeable asphalt □ Permeable concrete □ Other:	□ Sediment accumulation □ Grass/weeds growing □ Standing water □ Sink holes □ Staining (oil, etc.) □ Deterioration of surface material □ Structural problem □ Other:		□ **Permeable surface functioning as designed?** **If different from plan, note how it is different:**
Overflow/Outlet: □ Underdrain(s) □ Overflow inlet at curb □ Other:	□ Obstruction/clogging □ Flow by-passing pavement surface □ Not high enough to create storage on pavement surface □ Erosion □ Structural problem □ Other:		
Other			
Issues to Refer to Higher Authority:			
VERIFICATION	☐ **BMP is functioning properly and as designed for pollutant removal.** ☐ **BMP requires corrective or preventative maintenance or rehabilitation to maintain its function for pollutant removal. Actions to be completed within one year:** ☐ **BMP recommended to be downgraded for pollutant removal.**		

Other: Rainwater Harvesting. NOTE: Shaded cells to be used for BMP verification

Date of Inspection:_____ **Project/BMP Name:**_____ **Plan/BMP # if applicable:**_____

Type of Inspection: ☐ **Verification 1st Inspection for Permit Cycle** ☐ **Verification Re-Inspection To Confirm Corrective Actions**

BMP Type: ☐ **Stormwater Retrofit** ☐ **New LID Practice** ☐ **Old Stormwater Practice** ☐ **Homeowner BMP**

Date BMP Placed into Service:_____ **Site Address:**_____

Verification Inspector:_____ **Inspector Credential(s):**_____

Photo #s Taken at Site:_____ **Is BMP Still Present?** ☐ **YES** ☐ **NO**

Component:	***Check For:***	***Observations:***	***VERIFICATION***
Rainwater Harvesting			
Roof Area/Gutters	□ Overhanging branches □ Excessive debris □ Other:		□ **Contributing roof area conforms to plan?** **If different from plan, note how it is different:**
Pre-Treatment Filter: □ Vortex □ Roof washer □ Other □ None	□ Flow by-passes pre-treatment □ Needs maintenance □ Structural problem □ Other:		□ **Pre-Treatment present and functioning?** **If different from plan, note how it is different:**

Tank/Cistern: □ Above ground □ Underground □ Material:	□ Sediment accumulation (if possible to view) □ Structural problem/leaning □ Inadequate foundation □ Excessive algae growth □ Missing lids, screens □ Broken components □ Mosquito breeding □ Other:		□ **Tank/Cistern present, collecting water, and functioning properly?** **If different from plan, note how it is different:**
Plumbing components: □ Pumps □ Backflow preventer □ Covers □ Outlets/spigots □ None □ Other:	□ Missing pieces □ Damaged or non-functional components □ Other:		
Overflow: □ Downstream practice □ Vegetated area □ None □ Other:	□ Erosion □ Obstructed or clogged □ Other:		□ **Overflow stable?** **If different from plan or is unstable, note the conditions:**
Structural □ Roof drains/scuppers □ Other:	□ Obstructed, clogged □ Suspect leaks □ Broken components □ Other:		
Issues to Refer to Higher Authority:			
VERIFICATION	☐ **BMP is functioning properly and as designed for pollutant removal.** ☐ **BMP requires corrective or preventative maintenance or rehabilitation to maintain its function for pollutant removal. Actions to be completed within one year:** ☐ **BMP recommended to be downgraded for pollutant removal.**		

Vegetated Roofs. NOTE: Shaded cells to be used for BMP verification

Date of Inspection:_____ **Project/BMP Name:**_____ **Plan/BMP # if applicable:**_____

Type of Inspection: ☐ **Verification 1st Inspection for Permit Cycle** ☐ **Verification Re-Inspection To Confirm Corrective Actions**

BMP Type: ☐ **Stormwater Retrofit** ☐ **New LID Practice** ☐ **Old Stormwater Practice** ☐ **Homeowner BMP**

Date BMP Placed into Service:_____ **Site Address:**_____

_____

Verification Inspector:_____ **Inspector Credential(s):**_____

Photo #s Taken at Site:_____ **Is BMP Still Present?** ☐ **YES** ☐ **NO**

Component:	***Check For:***	***Observations:***	***VERIFICATION***
Type □ Intensive □ Extensive □ Not sure			□ **Vegetated roof present and functioning?** **If different from plan, note how it is different:**
Vegetation	□ Bare areas □ Dead/diseased/poor health □ Weeds/invasives □ Moss □ % coverage _____ □ Other:		□ **Vegetation generally conforms to plan OR vegetative cover is adequate?** **If different from plan, note how it is different:**
Structural components □ Roof drains/scuppers □ Rock drainage area □ Pavement □ Other:	□ Obstructed, clogged drains □ Erosion or loss of soil media □ Suspected leaks □ Standing water □ Damage to flashing □ Broken components □ Other:		□ **Structural components are intact and functioning properly.** **Note deficiencies**

Irrigation system □ Sprinkler □ Hose □ Temporary □ Permanent □ Timers □ Sensors	□ Not functioning properly		□ **Irrigation system intact and functioning properly** **Note Deficiencies**
Issues to Refer to Higher Authority:			
VERIFICATION	☐ **BMP is functioning properly and as designed for pollutant removal.** ☐ **BMP requires corrective or preventative maintenance or rehabilitation to maintain its function for pollutant removal. Actions to be completed within one year:** ☐ **BMP recommended to be downgraded for pollutant removal.**		