

CERTIFICATE

of Conformity

Registration No.: AK 50683814 0001
Report No.: CN25ZJN4 001
Holder: Fuzhou Tianyu Electric Co., Ltd
No.28 Yaoxi Road, Nanyu Town, Minhou County,
Fuzhou City,
350109 Fujian
P.R. China
Product: Power Transformer
(A Three-phase Outdoor Oil-immersed Power Transformer)

Type designation listed on the next page

The certificate of conformity refers to the above-mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned on the next page. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Date: 2025-07-13

Certification Body



Wencai Zhang



TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

CERTIFICATE

of Conformity

Registration No.: AK 50683814 0001

Product: Power Transformer
(A Three-phase Outdoor Oil-immersed Power Transformer)

Tested according to: IEC 60076-1:2011
IEC 60076-2:2011
IEC 60076-3:2013+A1
IEC 60076-5:2006
IEC 60076-10:2016
EN 50708-2-4:2022
EN 50464-4:2007+A1


Identification: Type Designation
S-M-1600/22-Tier2
Serial No.: BY04001

Manufacturing Plant:
Fuzhou Tianyu Electric Co., Ltd
No.28 Yaoxi Road, Nanyu Town, Minhou County, Fuzhou
City, 350109 Fujian P.R. China

IEC 60076-1:2011 sub-clauses: 11.1.4 h), 11.1.4 n),
11.2, 11.3, 11.4, 11.5, 11.8;
IEC 60076-2:2011;
IEC 60076-3:2013+AMD1:2018 sub-clauses: 10, 11.2,
11.3, 13;
IEC 60076-5:2006; IEC 60076-10:2016;
EN 50708-2-4:2022 sub-clause: 5
EN 50464-4:2007+A1:2011

Ratings:

Rated power (Sr)	:1600 kVA
Rated voltage (HV/LV) (Ur)	:22($\pm 2 \times 2.5\%$)/0.42 kV
Rated frequency (fr)	:50 Hz
Rated current (HV/LV) (Ir)	:41.99/2199 A
Rated insulation level (Um/LI/LIC/AC) of HV	:24/125/138/50 kV
Rated insulation level (Um/LI/LIC/AC) of LV	:1.1/20/22/10 kV
Rated insulation level (Um/LI/AC) of LVN	:1.1/20/10 kV
Cooling method	:ONAN



TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

© TÜV, TÜV and TÜV are registered trademarks. Utilisation and application requires prior approval.

CERTIFICATE

of Conformity

Identification:

Type Designation

S-M-1600/22-Tier2

Ratings:

Connection symbol

:Dyn5

Sound power level

:≤57 dB(A)

Short circuit impedance between HV and LV in reference to the rated power

:6.0% (±10%)

Load losses at 75 °C at rated frequency of 50 Hz

:≤12 kW

No-load current at rated voltage and frequency

:0.4% (+30%)

No-load losses at rated voltage and frequency

:≤1.08 kW

Remark: For the further ratings to see test report CN25ZJN4 001.



© TÜV, TÜV and TÜV are registered trademarks. Utilisation and application requires prior approval.

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg