



ECMPS Client Tool

Version 1.* 2022 Q2

Emissions Evaluation Report

September 7, 2022 12:32 PM

Facility Name: Lincoln Combustion Turbine

Facility Details

Facility ID (ORISPL): 7277
Monitoring Plan Location IDs: 11
State: NC
County: Lincoln County
Year/Quarter: 2021 Q1
Total Hours: 2160

Evaluation Results

General Errors

Severity	Check Code / Result	Result Message
INFORM	HOURGEN-13-B	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.

QA Status Errors

Unit/Stack/ Pipe	Category Description	Severity	Check Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
11	Fuel Flowmeter QA Status Evaluation	CRIT1	OOC-Event	You reported a QA Certification Event record for QACertEventCode 401 QACertEventDate 03/22/2021 for ComponentID 112, but you did not perform a subsequent accuracy test.	03/22/2021 07	03/22/2021 07	1
				You reported a QA Certification Event record for QACertEventCode 401 QACertEventDate 03/22/2021 for ComponentID 112, but you did not perform a subsequent PEI.	03/22/2021 07	03/22/2021 07	1