



ECMPS Client Tool

Version 1.* 22 Q1 Build 3

Emissions Evaluation Report

February 22, 2022 08:51 AM

Facility Name: Barry

Facility Details

Facility ID (ORISPL): 3
Monitoring Plan Location IDs: 5
State: AL
County: Mobile County
Year/Quarter: 2021 Q3
Total Hours: 2208

Evaluation Results

General Errors

Severity	Check Code / Result	Result Message
INFORM	HOURGEN-13-B	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.

Hourly Data Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
5	INFORM	HOUROP-32-H	Warning: The HourLoad reported in the Hourly Operating Data record is higher than the MaximumLoadValue in the Monitoring Load record reported in your monitoring plan. Sources are required to periodically (at least once annually) evaluate the appropriateness of these maximum values in the monitoring plan and make proper adjustments when necessary. You should investigate the cause of these exceedances and determine whether an adjustment to the MaximumLoadValue in your monitoring plan is necessary.	08/16/2021 12	08/16/2021 12	1
				09/13/2021 20	09/13/2021 20	1