



ECMPS Client Tool

Version 1.* 2022 Q1

Emissions Evaluation Report

May 13, 2022 02:33 PM

Facility Name: Crystal River

Facility Details

Facility ID (ORISPL): 628
Monitoring Plan Location IDs: 4
State: FL
County: Citrus County
Year/Quarter: 2021 Q3
Total Hours: 2208

Evaluation Results

General Errors

Severity	Check Code / Result	Result Message
INFORM	HOURGEN-13-B	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.

Hourly Data Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
4	CRIT1	MATSCHV-14-D	You reported a FormulaIdentifier in the MATS Derived Hourly Value record for HGRE, but you did not report a value for all the essential parameters needed to perform the calculation.	07/01/2021 00	07/01/2021 00	1
		MATSMHV-4-B	The MODCCode reported for MATS Monitor Hourly Value is invalid.	07/01/2021 00	07/01/2021 00	1
		MATSMHV-5-A	You did not report a PMA for the MATS Monitor Hourly Value.	07/01/2021 01	07/01/2021 01	1
		MATSMHV-6-C	The system type associated with the Monitoring System ID for the HGC MATS Monitor Hourly Value is not consistent with that parameter.	07/01/2021 01	07/01/2021 01	1
		MATSMHV-7-B	You reported a MATS Monitor Hourly Value MODCCode that is only used with backup or redundant backup monitoring systems.	07/01/2021 02	07/01/2021 02	1
		MATSMHV-8-A	You reported an MODCCode of 17 in the MATS Monitor Hourly Value record for HGC, indicating the use of a like-kind analyzer, but you have used a like-kind analyzer to monitor this parameter for more than 720 hours during this reporting period. You are not allowed to use a like-kind analyzer for more than 720 hours during a calendar year, unless the analyzer is identified as a non-redundant backup and a RATA is performed.	08/03/2021 10	08/03/2021 23	14
		MATSMHV-9-D	You reported an MODCCode of 17 in the MATS MHV record for HGC, which indicates that the component is a like-kind analyzer, but the ComponentID does not begin with LK.	07/01/2021 03	07/07/2021 22	164
				07/10/2021 22	07/10/2021 23	2
				07/11/2021 04	07/15/2021 17	110

Facility Name: Crystal River

Facility ID (ORISPL): 628

Emissions Evaluation Report

May 13, 2022 02:33 PM

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
4	CRIT1	MATSMHV-9-D	You reported an MODCCode of 17 in the MATS MHV record for HGC, which indicates that the component is a like-kind analyzer, but the ComponentID does not begin with LK.	07/15/2021 20	07/15/2021 22	3
				07/16/2021 01	07/16/2021 22	22
				07/17/2021 00	08/03/2021 23	432