



ECMPS Client Tool

Version 1.* 2022 Q1

Emissions Evaluation Report

May 12, 2022 12:08 PM

Facility Name: Vicinity Energy Philadelphia Edison Sta

Facility Details

Facility ID (ORISPL): 880006
Monitoring Plan Location IDs: 3
State: PA
County: Philadelphia County
Year/Quarter: 2021 Q4
Total Hours: 2208

Evaluation Results

General Errors

Severity	Check Code / Result	Result Message
CRIT1	HOURGEN-8-B	The Monitoring Plan associated with this quarterly emissions file has not been evaluated. You must evaluate the Monitoring Plan for this monitoring configuration in order to complete the evaluation of this emissions file.
	LME-11-B	The MonitoringSystemID reported in the LTFF record for MonitoringSystemID 101 is not a long-term fuel flow system.
INFORM	HOURGEN-13-B	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.
	HOURGEN-15-H	Warning: The LME Unit Default Test conducted to determine the default NOx emission rate for each of the following fuels have expired: Fuel Code(s) OIL. In subsequent reporting periods, you will need report substitute data until you perform another Unit Default Test. LME Unit Default Tests expire after five years.