



ECMPS Client Tool

Version 1.* 2022 Q2

Emissions Evaluation Report

September 13, 2022 05:05 PM

Facility Name: River Valley

Facility Details

Facility ID (ORISPL): 10671
Monitoring Plan Location IDs: CS1, 1A, 1B, 2A, 2B
State: OK
County: Le Flore County
Year/Quarter: 2021 Q4
Total Hours: 2208

Evaluation Results

General Errors

Severity	Check Code / Result	Result Message
INFORM	HOURGEN-13-B	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.

Hourly Data Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
CS1	INFORM	HOURCV-37-C	Warning: The UnadjustedHourlyValue reported in the DHV record for NOXR is in excess of the maximum value listed in the monitoring plan. Sources are required to periodically (at least once annually) evaluate the appropriateness of these maximum values in the monitoring plan and make proper adjustments when necessary. Adjustments may include the need to update Span and/or Default values. You should investigate the cause of these exceedances and determine whether adjustments to your monitoring systems or monitoring plan are necessary.	11/06/2021 06	11/06/2021 06	1