



ECMPS Client Tool

Version 1.* 2022 Q2

QA/Cert Test Evaluation Report

November 18, 2022 04:59 PM

Facility Name: Barry

Facility Details

Facility ID (ORISPL): 3
State: AL
County: Mobile County

Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
4	CYCLE	1 01/20/2015 17:14	CO2/CO2	CRIT1	CYCLE-7-A	The injection end date, hour, and/or minute for Gas Level ZERO is invalid.
				INFORM	CYCLE-5-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		2 01/20/2015 17:14	SO2/SO2	INFORM	CYCLE-5-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		3 01/20/2015 17:12	NOX/NOX	CRIT1	CYCLE-6-A	The injection begin date, hour, and/or minute for Gas Level HIGH is invalid.
				INFORM	CYCLE-5-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		HG1 03/15/2016 12:42	CMM/HG	CRIT1	CYCLE-8-A	You did not provide CalibrationGasValue, which is required for Gas Level ZERO.
				INFORM	CYCLE-5-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.