



# ECMPS Client Tool

Version 1.\* 2022 Q2

## Emissions Evaluation Report

June 27, 2022 12:58 PM

Facility Name: Clifty Creek

### Facility Details

Facility ID (ORISPL): 983  
Monitoring Plan Location IDs: CS046, 4, 5, 6  
State: IN  
County: Jefferson County  
Year/Quarter: 2020 Q1  
Total Hours: 2184

### Evaluation Results

#### General Errors

Severity	Check Code / Result	Result Message
INFORM	<a href="#">HOURGEN-13-B</a>	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.

#### QA Status Errors

Unit/Stack/ Pipe	Category Description	Severity	Check Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
CS046	FLOW Daily Calibration Status Evaluation	CRIT1	<a href="#">OOC-Event</a>	You reported a QA Certification Event record for QACertEventCode 301 QACertEventDate 01/15/2020 for Component ID 42A, but you did not perform a subsequent daily calibration test.	01/16/2020 07	01/16/2020 07	1

#### Hourly Data Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
CS046	CRIT1	<a href="#">HOURMHV-14-A</a>	You reported an MODCCode of 01 in the MHV record for FLOW, but MonitoringSystemID 4LF is not a primary system.	01/16/2020 07	01/16/2020 07	1