



ECMPS Client Tool

Version 1.* 2022 Q2

QA/Cert Test Evaluation Report

November 19, 2022 07:01 PM

Facility Name: Lincoln Combustion Turbine

Facility Details

Facility ID (ORISPL): 7277
State: NC
County: Lincoln County

Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
6	FFACC	U06G-033119 10/01/2021 11:00	061/OFFM	FATAL	FFACC-14-B	A transmitter transducer test with this test number has been previously submitted. You must assign a different test number.
		U6O-082119 08/21/2019 15:00	061/OFFM	CRIT1	FFACC-11-E	You reported a TestResultCode of "FAILED", but the results recalculated or determined from the other reported values indicate that the test passed.
				INFORM	FFACC-3-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
	FFACCTT	U06G-052521 05/25/2021 09:00	062/GFFM	INFORM	FFACCTT-4-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.