



# ECMPS Client Tool

Version 1.\* 2022 Q2

## Emissions Evaluation Report

September 7, 2022 05:43 PM

Facility Name: Bridgeport Harbor Station

### Facility Details

Facility ID (ORISPL): 568  
Monitoring Plan Location IDs: BHB5  
State: CT  
County: Fairfield County  
Year/Quarter: 2021 Q4  
Total Hours: 2208

### Evaluation Results

#### General Errors

Severity	Check Code / Result	Result Message
CRIT1	<a href="#">HOURGEN-8-B</a>	The Monitoring Plan associated with this quarterly emissions file has not been evaluated. You must evaluate the Monitoring Plan for this monitoring configuration in order to complete the evaluation of this emissions file.
INFORM	<a href="#">HOURGEN-13-B</a>	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.

#### QA Status Errors

Unit/Stack/ Pipe	Category Description	Severity	Check Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
BHB5	Fuel Flowmeter QA Status Evaluation	CRIT1	<a href="#">OOC-Inprogress</a> <a href="#">Fuel Flow to Load</a> <a href="#">Test Required</a>	The accuracy test status for ComponentID 504 could not be determined because expected "INPROG" Fuel-Flow-To-Load Test(s) for MonitoringSystemID GAS are missing in quarter(s) 2019 Q4.	10/01/2021 00	10/13/2021 23	312
					10/23/2021 08	10/23/2021 09	2
					10/23/2021 12	10/23/2021 12	1
					10/23/2021 16	10/23/2021 19	4
					10/23/2021 23	12/31/2021 23	1657
				The accuracy test status for ComponentID 505 could not be determined because expected "INPROG" Fuel-Flow-To-Load Test(s) for MonitoringSystemID GAS are missing in quarter(s) 2019 Q4.	10/01/2021 00	10/13/2021 23	312
					10/23/2021 08	10/23/2021 09	2
					10/23/2021 12	10/23/2021 12	1
					10/23/2021 16	10/23/2021 19	4
					10/23/2021 23	12/31/2021 23	1657
				The PEI status for ComponentID 505 could not be determined because expected "INPROG" Fuel-Flow-To-Load Test(s) for MonitoringSystemID GAS are missing in quarter(s) 2019 Q4.	10/01/2021 00	10/13/2021 23	312
					10/23/2021 08	10/23/2021 09	2
					10/23/2021 12	10/23/2021 12	1

Facility Name: Bridgeport Harbor Station

## Emissions Evaluation Report

Facility ID (ORISPL): 568

September 7, 2022 05:43 PM

Unit/Stack/ Pipe	Category Description	Severity	Check Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
BHB5	Fuel Flowmeter QA Status Evaluation	CRIT1	<a href="#">OOC-Inprogress</a> <a href="#">Fuel Flow to Load</a> <a href="#">Test Required</a>	The PEI status for ComponentID 505 could not be determined because expected "INPROG" Fuel-Flow-To-Load Test(s) for MonitoringSystemID GAS are missing in quarter(s) 2019 Q4.	10/23/2021 16	10/23/2021 19	4
					10/23/2021 23	12/31/2021 23	1657