



ECMPS Client Tool

Version 1.* 2022 Q2

QA/Cert Test Evaluation Report

October 12, 2022 04:23 PM

Facility Name: Lincoln Combustion Turbine

Facility Details

Facility ID (ORISPL): 7277
State: NC
County: Lincoln County

Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
5	APPE	05NOX2016-1 02/10/2016 00:30	410/NOXE	CRIT1	APPE-8-A	There are missing or non-sequential OperatingLevelForRun and RunNumbers in this test. Run numbers must begin with 1 and be consecutive within the entire test or within each operating level. The lowest OperatingLevelForRun must be equal to 1.
					APPE-11-A	You reported an EndDate, EndHour, and EndMinute for the Appendix E test that is not the same as the EndDate, EndHour, and EndMinute of the last run in the test.
					APPE-18-B	You defined an invalid RunNumber for Operating Level 1 Run Number 0. This value must be greater than zero and less than 20,000.
					APPE-43-A	You have defined an inconsistent number of fuel flow records for this test. There must be the same combination of supporting fuel flow records for each run.
		05NOX2016-2 02/11/2016 15:59	400/NOXE	INFORM	APPE-4-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
				CRIT1	APPE-19-A	The BeginDate, BeginHour, and/or BeginMinute for Operating Level 1 Run Number 1 is invalid.
		05NOX2021-1 02/10/2021 14:49	410/NOXE	INFORM	APPE-4-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
				CRIT1	APPE-20-A	The EndDate, EndHour, and/or EndMinute for Operating Level 1 Run Number 1 are invalid.
		05NOX2021-2 02/11/2021 15:20	400/NOXE	INFORM	APPE-4-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
				CRIT1	APPE-21-A	The value -1 in the field ResponseTime for Operating Level 1 Run Number 1 is not within the range of valid values from 0 to 800.
				INFORM	APPE-4-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.