



ECMPS Client Tool

Version 1.* 2022 Q2

QA/Cert Test Evaluation Report

October 12, 2022 04:22 PM

Facility Name: Lincoln Combustion Turbine

Facility Details

Facility ID (ORISPL): 7277
State: NC
County: Lincoln County

Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
3	APPE	03NOX2016-1 02/08/2016 17:34	410/NOXE	CRIT1	APPE-10-A	You reported a test BeginDate, BeginHour, and BeginMinute that is not the same as the BeginDate, BeginHour, and BeginMinute of the first run in the Appendix E test.
				INFORM	APPE-4-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		03NOX2016-2 02/10/2016 16:21	400/NOXE	CRIT1	APPE-11-A	You reported an EndDate, EndHour, and EndMinute for the Appendix E test that is not the same as the EndDate, EndHour, and EndMinute of the last run in the test.
				INFORM	APPE-4-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		03NOX2021-1 02/08/2021 16:44	410/NOXE	FATAL		Failed executing method 'AppendixE40'. Index was outside the bounds of the array. at ECMPS.Checks.AppendixEChecks.cAppendixEChecks.AppendixE40(cCategory Category, Boolean& Log)
						Failed executing method 'AppendixE41'. Index was outside the bounds of the array. at ECMPS.Checks.AppendixEChecks.cAppendixEChecks.AppendixE41(cCategory Category, Boolean& Log)
				CRIT1	APPE-13-B	The value in the field OperatingLevelForRun for Operating Level -1 is not within the range of valid values from 1 to 99.
					APPE-38-A	The Appendix E test contains fewer than three run records for Operating Level -1. A minimum of three runs are required at each operating level.
				INFORM	APPE-4-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		03NOX2021-2 02/09/2021 15:28	400/NOXE	CRIT1	APPE-14-C	The value 3.100 in the field MeanReferenceValue for Operating Level 1 is not within the range of valid values from 0 to 3.
					APPE-40-A	The MeanReferenceValue reported for Operating Level 1 is inconsistent with the value recalculated from the run data for the test.
				INFORM	APPE-4-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.