



ECMPS Client Tool

Version 1.* 2022 Q2

QA/Cert Test Evaluation Report

November 16, 2022 03:22 PM

Facility Name: IPL - Eagle Valley Generating Station

Facility Details

Facility ID (ORISPL): 991
State: IN
County: Morgan County

Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
GT1	ONOFF	GT1-3 06/24/2021 07	C02/BGFF	CRIT1	ONOFF-1-B	The ComponentTypeCode in the monitoring plan is BGFF. This type of component does not require an online offline calibration test.
					TEST-9-A	You have not reported a valid monitoring plan span record that was active during the test.
					TEST-22-B	A Monitoring Plan associated with this test has not been evaluated. You must evaluate all active and future Monitoring Plans containing the location in this test in order to complete the evaluation of this test.
				INFORM	ONOFF-23-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.