



ECMPS Client Tool

Version 1.* 2022 Q2

QA/Cert Test Evaluation Report

November 16, 2022 03:28 PM

Facility Name: Bethpage Energy Center

Facility Details

Facility ID (ORISPL): 50292
State: NY
County: Nassau County

Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
GT2	ONOFF	ONOF-Q12017-213-4 01/02/2017 08	213/NOX	CRIT1	ONOFF-5-A	The Offline Upscale injection Date and/or Hour is invalid.
					ONOFF-41-A	You did not provide OnlineZeroAPSIndicator, which is required for this test.
				INFORM	ONOFF-23-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		ONOF-Q12017-232-3 01/02/2017 08	232/CO2	CRIT1	ONOFF-6-A	You did not provide OfflineUpscaleMeasuredValue, which is required for this test.
				INFORM	ONOFF-23-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
					ONOFF-28-A	The software could not evaluate the online offline calibration test calculations reported for the offline upscale injection, because of the errors listed above.