



ECMPS Client Tool

Version 1.* 2022 Q2

QA/Cert Test Evaluation Report

November 19, 2022 06:59 PM

Facility Name: Lincoln Combustion Turbine

Facility Details

Facility ID (ORISPL): 7277
State: NC
County: Lincoln County

Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
3	FFACC	U3O-072417 07/24/2000 11:00	031/OFFM	NONCRIT	FFACC-6-B	You did not provide TestReasonCode for this test. This information will be required for ECMPS submissions.
				INFORM	FFACC-3-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		U3O-082119 08/21/2019 18:00	031/OFFM	CRIT1	FFACC-4-E	You did not report a ReinstallationDate for an accuracy test that, according to the accuracy test method, was not performed in-line.
					FFACC-5-A	You did not provide ReinstallationHour, which is required for this test.
				INFORM	FFACC-3-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.