



ECMPS Client Tool

Version 1.* 2022 Q2

QA/Cert Test Evaluation Report

October 7, 2022 09:18 PM

Facility Name: Barry

Facility Details

Facility ID (ORISPL): 3
Monitoring Plan Location IDs: 5
State: AL
County: Mobile County

Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
5	RATA	200905050746AD4 05/05/2009 11:00	AD4/FLOW	CRIT1	RATA-43-A	According to the run records of this RATA, the average gross unit load of Operating Level M is greater than or equal to the average gross unit load of Operating Level H.
					TEST-22-B	A Monitoring Plan associated with this test has not been evaluated. You must evaluate all active and future Monitoring Plans containing the location in this test in order to complete the evaluation of this test.
				CRIT2	RATA-38-B	The average gross unit load recalculated from the values in the run records for Operating Level M is not within the mid level operating range defined in the load record.
				INFORM	RATA-49-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		201503250954ADD 03/25/2015 12:12	ADD/FLOW	CRIT1	RATA-42-A	According to the run records of this RATA, the average gross unit load of Operating Level L is greater than or equal to the average gross unit load of Operating Level M.
				CRIT2	RATA-38-A	The average gross unit load recalculated from the values in the run records for Operating Level L is not within the low level operating range defined in the load record.
				INFORM	RATA-49-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
					RATA-60-A	You have reported a ReferenceMethodCode for Operating Level H that does not indicate the use of a rectangular duct WAF, but you have reported a RectangularDuctWAF record for the location. If you use a rectangular duct WAF, you must report a reference method of 2J, 2FJ, or 2GJ.
						You have reported a ReferenceMethodCode for Operating Level L that does not indicate the use of a rectangular duct WAF, but you have reported a RectangularDuctWAF record for the location. If you use a rectangular duct WAF, you must report a reference method of 2J, 2FJ, or 2GJ.
						You have reported a ReferenceMethodCode for Operating Level M that does not indicate the use of a rectangular duct WAF, but you have reported a RectangularDuctWAF record for the location. If you use a rectangular duct WAF, you must report a reference method of 2J, 2FJ, or 2GJ.
		201902211047ADD 02/21/2019 11:36	ADD/FLOW	INFORM	RATA-49-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.

Facility Name: Barry

Facility ID (ORISPL): 3

QA/Cert Test Evaluation Report

October 7, 2022 09:18 PM

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
5	RATA	201902211047ADD 02/21/2019 11:36	ADD/FLOW	INFORM	RATA-60-A	You have reported a ReferenceMethodCode for Operating Level H that does not indicate the use of a rectangular duct WAF, but you have reported a RectangularDuctWAF record for the location. If you use a rectangular duct WAF, you must report a reference method of 2J, 2FJ, or 2GJ.
						You have reported a ReferenceMethodCode for Operating Level L that does not indicate the use of a rectangular duct WAF, but you have reported a RectangularDuctWAF record for the location. If you use a rectangular duct WAF, you must report a reference method of 2J, 2FJ, or 2GJ.
		201903130722ADE 03/13/2019 14:41	ADE/HG	CRIT1	RATA-44-A	You reported a test Begin Date, Hour, and Minute that is not the same as the BeginDate, BeginHour, and BeginMinute of the first run in the RATA.
				INFORM	RATA-49-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		202003300811ADA 03/30/2020 13:53	ADA/SO2	CRIT1	RATA-20-A	You did not provide StandardDeviationDifference, which is required for Operating Level M.
				INFORM	RATA-49-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
					RATA-132-A	You have reported more than 3 decimal places for ConfidenceCoefficient, MeanCEMValue, MeanDifference, and MeanRATAReferenceValue, which is not permitted by Part 75.
		202003300811ADB 03/30/2020 13:53	ADB/NOX	CRIT1	RATA-22-A	You have not reported the required value in the field TValue for Operating Level M.
				INFORM	RATA-49-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
					RATA-132-A	You have reported more than 3 decimal places for ConfidenceCoefficient, MeanCEMValue, MeanRATAReferenceValue, and StandardDeviationDifference, which is not permitted by Part 75.
		202003300811ADC 03/30/2020 13:53	ADC/CO2	CRIT1	RATA-21-A	You did not provide ConfidenceCoefficient, which is required for Operating Level M.
				INFORM	RATA-49-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		202003301130ADE 03/30/2020 17:48	ADE/HG	CRIT1	RATA-23-B	You defined an invalid AverageGrossUnitLoad for Operating Level M. This value must be greater than zero and less than 20,000.
				INFORM	RATA-49-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		202003310710ADD 03/31/2020 10:50	ADD/FLOW	CRIT1	RATA-24-A	You did not provide RelativeAccuracy, which is required for Operating Level H.
				INFORM	RATA-49-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
					RATA-132-A	You have reported more than 3 decimal places for ConfidenceCoefficient and StandardDeviationDifference, which is not permitted by Part 75. You have reported more than 3 decimal places for ConfidenceCoefficient, MeanCEMValue, MeanDifference, MeanRATAReferenceValue, and StandardDeviationDifference, which is not permitted by Part 75.

Facility Name: Barry

Facility ID (ORISPL): 3

QA/Cert Test Evaluation Report

October 7, 2022 09:18 PM

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
5	RATA	202102230833ADE 02/23/2021 16:17	ADE/HG	CRIT1	RATA-31-B	The run End Time is earlier than the run Begin Time for Operating Level M Run Number 10.
					RATA-45-A	You reported a test EndDate, Hour, and Minute that is not the same as the EndDate, Hour, and Minute of the last run in the RATA test.
				CRIT2	RATA-32-C	The run for Operating Level M Run Number 10 was less than 30 minutes. Each run must be at least 30 minutes in duration.
				INFORM	RATA-35-B	The software could not evaluate the RATA calculations reported for Operating Level M, because of the errors listed above.
					RATA-49-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		202102230957ADA 02/23/2021 14:38	ADA/SO2	CRIT1	RATA-29-A	You did not provide RunStatusCode, which is required for Operating Level M Run Number 9.
					RATA-34-B	The RATA for Operating Level M contains fewer than nine RATA run records with a run status of "RUNUSED". A minimum of nine runs are required for each complete operating level test.
				INFORM	RATA-35-B	The software could not evaluate the RATA calculations reported for Operating Level M, because of the errors listed above.
					RATA-49-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
					RATA-132-A	You have reported more than 3 decimal places for ConfidenceCoefficient, MeanCEMValue, MeanDifference, MeanRATAReferenceValue, and StandardDeviationDifference, which is not permitted by Part 75.
		202102230957ADB 02/23/2021 14:38	ADB/NOX	CRIT1	RATA-30-A	The BeginDate, BeginHour, and/or BeginMinute for Operating Level M Run Number 9 is invalid.
				INFORM	RATA-35-B	The software could not evaluate the RATA calculations reported for Operating Level M, because of the errors listed above.
					RATA-49-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
					RATA-132-A	You have reported more than 3 decimal places for ConfidenceCoefficient, MeanCEMValue, MeanDifference, MeanRATAReferenceValue, and StandardDeviationDifference, which is not permitted by Part 75.
		202102230957ADC 02/23/2021 14:38	ADC/CO2	CRIT1	RATA-26-A	You did not provide GrossUnitLoad, which is required for Operating Level M Run Number 9.
				CRIT2	RATA-38-B	The average gross unit load recalculated from the values in the run records for Operating Level M is not within the mid level operating range defined in the load record.
				INFORM	RATA-49-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.

Facility Name: Barry

Facility ID (ORISPL): 3

QA/Cert Test Evaluation Report

October 7, 2022 09:18 PM

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
5	RATA	202102240736ADD 02/24/2021 08:26	ADD/FLOW	CRIT1	RATA-28-C	You did not report a Flow Run record for Operating Level L Run Number 1. When a RATA is performed using method 2F or 2G, Flow Run record must be reported for each run used in the relative accuracy calculation.
						You did not report a Flow Run record for Operating Level L Run Number 2. When a RATA is performed using method 2F or 2G, Flow Run record must be reported for each run used in the relative accuracy calculation.
						You did not report a Flow Run record for Operating Level L Run Number 3. When a RATA is performed using method 2F or 2G, Flow Run record must be reported for each run used in the relative accuracy calculation.
						You did not report a Flow Run record for Operating Level L Run Number 4. When a RATA is performed using method 2F or 2G, Flow Run record must be reported for each run used in the relative accuracy calculation.
						You did not report a Flow Run record for Operating Level L Run Number 5. When a RATA is performed using method 2F or 2G, Flow Run record must be reported for each run used in the relative accuracy calculation.
						You did not report a Flow Run record for Operating Level L Run Number 6. When a RATA is performed using method 2F or 2G, Flow Run record must be reported for each run used in the relative accuracy calculation.
						You did not report a Flow Run record for Operating Level L Run Number 7. When a RATA is performed using method 2F or 2G, Flow Run record must be reported for each run used in the relative accuracy calculation.
						You did not report a Flow Run record for Operating Level L Run Number 8. When a RATA is performed using method 2F or 2G, Flow Run record must be reported for each run used in the relative accuracy calculation.
						You did not report a Flow Run record for Operating Level L Run Number 9. When a RATA is performed using method 2F or 2G, Flow Run record must be reported for each run used in the relative accuracy calculation.
				INFORM	RATA-55-A	You did not provide CO2OrO2ReferenceMethodCode, which is required for Operating Level L.
					RATA-56-A	You did not provide StackDiameter, which is required for Operating Level L.
					RATA-57-A	You did not provide StackArea, which is required for Operating Level L.
				INFORM	RATA-35-B	The software could not evaluate the RATA calculations reported for Operating Level L, because of the errors listed above.
					RATA-49-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.