



ECMPS Client Tool

Version 1.* 2022 Q2

QA/Cert Test Evaluation Report

November 20, 2022 04:58 PM

Facility Name: Barry

Facility Details

Facility ID (ORISPL): 3
Monitoring Plan Location IDs: 4
State: AL
County: Mobile County

Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
4	7DAY	201501250645CO2 01/31/2015 06:50	CO2/CO2	CRIT1	TEST-8-A	You did not provide SpanScaleCode, which is required for this test.
					TEST-22-A	A Monitoring Plan associated with this test has critical errors. You must correct all active and future Monitoring Plans containing the location in this test in order to submit this test to be loaded on EPA's host system.
				INFORM	SEVNDAY-15-A	The software could not evaluate the Zero injection calculations reported for Zero Injection Date 01/25/2015, because of the errors listed above.
						The software could not evaluate the Zero injection calculations reported for Zero Injection Date 01/26/2015, because of the errors listed above.
						The software could not evaluate the Zero injection calculations reported for Zero Injection Date 01/27/2015, because of the errors listed above.
						The software could not evaluate the Zero injection calculations reported for Zero Injection Date 01/28/2015, because of the errors listed above.
						The software could not evaluate the Zero injection calculations reported for Zero Injection Date 01/29/2015, because of the errors listed above.
						The software could not evaluate the Zero injection calculations reported for Zero Injection Date 01/30/2015, because of the errors listed above.
						The software could not evaluate the Zero injection calculations reported for Zero Injection Date 01/31/2015, because of the errors listed above.

Facility Name: Barry

Facility ID (ORISPL): 3

QA/Cert Test Evaluation Report

November 20, 2022 04:58 PM

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
4	7DAY	201501250645CO2 01/31/2015 06:50	CO2/CO2	INFORM	SEVNDAY-16-A	The software could not evaluate the Upscale injection calculations reported for Zero Injection Date 01/25/2015, because of the errors listed above.
						The software could not evaluate the Upscale injection calculations reported for Zero Injection Date 01/26/2015, because of the errors listed above.
						The software could not evaluate the Upscale injection calculations reported for Zero Injection Date 01/27/2015, because of the errors listed above.
						The software could not evaluate the Upscale injection calculations reported for Zero Injection Date 01/28/2015, because of the errors listed above.
						The software could not evaluate the Upscale injection calculations reported for Zero Injection Date 01/29/2015, because of the errors listed above.
						The software could not evaluate the Upscale injection calculations reported for Zero Injection Date 01/30/2015, because of the errors listed above.
						The software could not evaluate the Upscale injection calculations reported for Zero Injection Date 01/31/2015, because of the errors listed above.
	AAA 01/31/2015 00:00	NAX/NOX	CRIT1	SEVNDAY-21-A	TEST-9-C	The test contains fewer than seven calibration injection records.
						The tested component is not part of any monitoring system.
						A Monitoring Plan associated with this test has critical errors. You must correct all active and future Monitoring Plans containing the location in this test in order to submit this test to be loaded on EPA's host system.
	LINE	20210713113539NOX 07/13/2021 12:48	NOX/NOX	FATAL		Failed executing method 'ThrowInvalidOperationException'. Nullable object must have a value. at System.ThrowHelper.ThrowInvalidOperationException(ExceptionResource resource) at ECMPS.Checks.TestChecks.cPgvpChecks.PGVP4(cCategory category, Boolean& log)
				CRIT1	TEST-1-A	You did not provide BeginDate, which is required for this test.
					TEST-22-A	A Monitoring Plan associated with this test has critical errors. You must correct all active and future Monitoring Plans containing the location in this test in order to submit this test to be loaded on EPA's host system.
				INFORM	LINEAR-4-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		20210713113539SO2 07/13/2021 12:48	SO2/SO2	CRIT1	TEST-2-B	The value 24 in the field BeginHour for this test is not within the range of valid values from 0 to 23.
					TEST-22-A	A Monitoring Plan associated with this test has critical errors. You must correct all active and future Monitoring Plans containing the location in this test in order to submit this test to be loaded on EPA's host system.
				INFORM	LINEAR-4-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.

Facility Name: Barry

Facility ID (ORISPL): 3

QA/Cert Test Evaluation Report

November 20, 2022 04:58 PM

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
4	ONOFF	1 03/23/2015 06	CO2/CO2	CRIT1	TEST-22-A	A Monitoring Plan associated with this test has critical errors. You must correct all active and future Monitoring Plans containing the location in this test in order to submit this test to be loaded on EPA's host system.
				INFORM	ONOFF-23-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		2 03/23/2015 06	NOX/NOX	CRIT1	TEST-22-A	A Monitoring Plan associated with this test has critical errors. You must correct all active and future Monitoring Plans containing the location in this test in order to submit this test to be loaded on EPA's host system.
				INFORM	ONOFF-23-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		3 03/23/2015 06	SO2/SO2	CRIT1	TEST-22-A	A Monitoring Plan associated with this test has critical errors. You must correct all active and future Monitoring Plans containing the location in this test in order to submit this test to be loaded on EPA's host system.
				INFORM	ONOFF-23-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		4 03/23/2015 05	FLO/FLOW	CRIT1	TEST-22-A	A Monitoring Plan associated with this test has critical errors. You must correct all active and future Monitoring Plans containing the location in this test in order to submit this test to be loaded on EPA's host system.
				INFORM	ONOFF-23-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
	RATA	202107260542ABF 08/02/2021 03:22	ABF/HG	CRIT1	TEST-22-A	A Monitoring Plan associated with this test has critical errors. You must correct all active and future Monitoring Plans containing the location in this test in order to submit this test to be loaded on EPA's host system.
				INFORM	RATA-49-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		202107260833ABA 08/02/2021 16:01	ABA/SO2	CRIT1	TEST-3-C	The value 61 in the field BeginMinute for this test is not within the range of valid values from 0 to 59.
					TEST-22-A	A Monitoring Plan associated with this test has critical errors. You must correct all active and future Monitoring Plans containing the location in this test in order to submit this test to be loaded on EPA's host system.
				INFORM	RATA-49-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
					RATA-132-A	You have reported more than 3 decimal places for ConfidenceCoefficient, MeanCEMValue, MeanDifference, MeanRATAReferenceValue, and StandardDeviationDifference, which is not permitted by Part 75.
		202107260833ABB 08/02/2021 24:01	ABB/NOX	CRIT1	TEST-5-B	The value 24 in the field EndHour for this test is not within the range of valid values from 0 to 23.
					TEST-22-A	A Monitoring Plan associated with this test has critical errors. You must correct all active and future Monitoring Plans containing the location in this test in order to submit this test to be loaded on EPA's host system.

Facility Name: Barry

Facility ID (ORISPL): 3

QA/Cert Test Evaluation Report

November 20, 2022 04:58 PM

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
4	RATA	202107260833ABB 08/02/2021 24:01	ABB/NOX	INFORM	RATA-132-A	You have reported more than 3 decimal places for ConfidenceCoefficient, MeanCEMValue, MeanDifference, MeanRATAReferenceValue, and StandardDeviationDifference, which is not permitted by Part 75.
		202107260833ABC 08/02/2021 16:61	ABC/CO2	CRIT1	TEST-6-C	The value 61 in the field EndMinute for this test is not within the range of valid values from 0 to 59.
					TEST-22-A	A Monitoring Plan associated with this test has critical errors. You must correct all active and future Monitoring Plans containing the location in this test in order to submit this test to be loaded on EPA's host system.
				INFORM	RATA-132-A	You have reported more than 3 decimal places for ConfidenceCoefficient, MeanCEMValue, MeanDifference, MeanRATAReferenceValue, and StandardDeviationDifference, which is not permitted by Part 75.
		202108021047ABD 07/02/2021 14:41	ABD/FLOW	CRIT1	RATA-45-A	You reported a test EndDate, Hour, and Minute that is not the same as the EndDate, Hour, and Minute of the last run in the RATA test.
					TEST-7-A	You reported EndDate, EndHour, and EndMinute which is prior to or equal to BeginDate, BeginHour, and BeginMinute for this test.
					TEST-22-A	A Monitoring Plan associated with this test has critical errors. You must correct all active and future Monitoring Plans containing the location in this test in order to submit this test to be loaded on EPA's host system.
				INFORM	RATA-49-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
					RATA-132-A	You have reported more than 3 decimal places for ConfidenceCoefficient, MeanCEMValue, MeanDifference, MeanRATAReferenceValue, and StandardDeviationDifference, which is not permitted by Part 75.