



ECMPS Client Tool

Version 1.* 2022 Q2

QA/Cert Test Evaluation Report

October 12, 2022 04:23 PM

Facility Name: Lincoln Combustion Turbine

Facility Details

Facility ID (ORISPL): 7277
State: NC
County: Lincoln County

Evaluation Results

| Unit/Stack Identifier | Test Type | Test Number Test Date/Hour | Sys / Comp ID / Type | Severity | Check Code | Result |
|-----------------------|-----------|---------------------------------|-------------------------|----------|---------------------------|---|
| 6 | APPE | 06NOX2016-1 02/10/2016 15:52 | 410/NOXE | CRIT1 | APPE-22-A | You did not provide ReferenceValue, which is required for Operating Level 1 Run Number 1. |
| | | | | INFORM | APPE-4-C | This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval. |
| | | 06NOX2016-2 02/11/2016 15:59 | 400/NOXE | CRIT1 | APPE-23-B | You defined an invalid HourlyHeatInputRate for Operating Level 1 Run Number 1. This value must be greater than zero and less than 20,000. |
| | | | | | APPE-41-A | The AverageHourlyHeatInputRate reported for Operating Level 1 is inconsistent with the value recalculated from the run and fuel data for the operating level. |
| | | | | INFORM | APPE-4-C | This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval. |
| | | 06NOX2021-1 02/10/2021 14:49 | 410/NOXE | CRIT1 | APPE-24-B | You defined an invalid TotalHeatInput for Operating Level 1 Run Number 1. This value must be greater than zero and less than 20,000. |
| | | | | INFORM | APPE-4-C | This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval. |
| | | 06NOX2021-2 02/11/2021 15:20 | 400/NOXE | CRIT1 | APPE-26-B | You reported a value for OilVolume and/or OilVolumeUnitsOfMeasureCode in the oil flow record for Operating Level 1 Run Number 1 Oil System ID 100. You must not report a value in this field if you are using an OILM system. |
| | | | | INFORM | APPE-4-C | This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval. |