



# ECMPS Client Tool

Version 1.\* 2021 Q4

## Emissions Evaluation Report

January 14, 2022 02:56 PM

**Facility Name:** Barry

### Facility Details

Facility ID (ORISPL): 3  
Monitoring Plan Location IDs: 6A  
State: AL  
County: Mobile County  
Year/Quarter: 2021 Q3  
Total Hours: 2208

### Evaluation Results

#### General Errors

Severity	Check Code / Result	Result Message
CRIT1	<a href="#">HOURGEN-8-B</a>	The Monitoring Plan associated with this quarterly emissions file has not been evaluated. You must evaluate the Monitoring Plan for this monitoring configuration in order to complete the evaluation of this emissions file.
INFORM	<a href="#">HOURGEN-13-B</a>	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.

#### Test Data Errors

Unit/Stack/ Pipe	Test Type	Test Date/Hour	Sys / Comp ID	Sys / Comp Type / Scale	Severity	Check Code	Result Message
6A	DAYCAL	09/17/2021 06:46	CD1	CO2/H	CRIT1	<a href="#">DAYCAL-5-A</a>	You have not reported a valid monitoring plan span record that was active during the test for Location 6A, Component CD1 and Type CO2 at 09/17/2021 6:46:00 AM.
					INFORM	<a href="#">DAYCAL-20-A</a>	The software could not evaluate the zero-level injection calculations reported for Location 6A, Component CD1 and Type CO2 at 09/17/2021 6:46:00 AM, because of the errors listed above.
						<a href="#">DAYCAL-21-A</a>	The software could not evaluate the upscale injection calculations reported for Location 6A, Component CD1 and Type CO2 at 09/17/2021 6:46:00 AM, because of the errors listed above.