



ECMPS Client Tool

Version 1.* 2022 Q2

QA/Cert Test Evaluation Report

October 14, 2022 06:01 PM

Facility Name: Thomas A. Smith Energy Facility

Facility Details

Facility ID (ORISPL): 55382
State: GA
County: Murray County

Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
CCCT1	7DAY	112 05/22/2021 09:19	112/NOX	CRIT2	SEVNDAY-31-B	You reported an OnlineOfflineIndicator for Zero Injection Date 05/16/2021 that indicates that the unit was offline, but 7-day calibration test injections must be performed when the unit is online.
				INFORM	SEVNDAY-5-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
					TEST-21-A	IMPORTANT FYI: This test was determined to be "INVALID" due to one or more Critical Level 2 errors. The reported data indicate that the test was not performed according to the requirements and therefore cannot be used to validate emissions data. Unless you make corrections to the test data and re-run the evaluation, this test will be disregarded by the emissions evaluation routine. If you are unable to eliminate the Critical Level 2 error(s) by correcting the test data but you believe this test should be considered valid, contact your CAMD analyst.
		122 05/22/2021 09:24	122/O2	CRIT1	SEVNDAY-33-A	You did not provide UpscaleAPSIndicator, which is required for Zero Injection Date 05/16/2021.
				INFORM	SEVNDAY-5-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		4 06/18/2019 08:12	121/O2	CRIT1	SEVNDAY-32-A	You did not provide ZeroAPSIndicator, which is required for Zero Injection Date 06/12/2019.
				INFORM	SEVNDAY-5-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.