



# ECMPS Client Tool

Version 1.\* 2022 Q2

## QA/Cert Test Evaluation Report

November 19, 2022 07:00 PM

**Facility Name:** Lincoln Combustion Turbine

### Facility Details

Facility ID (ORISPL): 7277  
State: NC  
County: Lincoln County

### Evaluation Results

| Unit/Stack Identifier | Test Type | Test Number<br>Test Date/Hour  | Sys / Comp<br>ID / Type | Severity | Check Code                 | Result  |
|-----------------------|-----------|--------------------------------|-------------------------|----------|----------------------------|---|
| 5                     | FFACC     | U5O-072417<br>07/24/2017 11:00 | 051/OFFM                | CRIT1    | <a href="#">FFACC-9-A</a>  | You did not provide MidFuelAccuracy, which is required for this test.   |
|                       |           |                                |                         | INFORM   | <a href="#">FFACC-3-C</a>  | This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.                 |
|                       |           | U5O-082119<br>08/21/2019 15:00 | 051/OFFM                | CRIT1    | <a href="#">FFACC-10-B</a> | The value -1.0 in the field HighFuelAccuracy for this test is not within the range of valid values. This value must be greater than or equal to zero. |
|                       |           |                                |                         | INFORM   | <a href="#">FFACC-3-C</a>  | This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.                 |