



ECMPS Client Tool

Version 1.* 2022 Q2

QA/Cert Test Evaluation Report

October 12, 2022 04:22 PM

Facility Name: Lincoln Combustion Turbine

Facility Details

Facility ID (ORISPL): 7277
State: NC
County: Lincoln County

Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
4	APPE	04NOX2016-1 02/08/2016 17:34	410/NOXE	CRIT1	APPE-15-B	The value 0.0 in the field FFactor for Operating Level 1 is not within the range of valid values from 1000 to 22000.
				INFORM	APPE-4-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		04NOX2016-2 02/09/2016 16:21	400/NOXE	CRIT1	APPE-9-A	The test was conducted at the same time as another Appendix E test for MonitoringSystemID 400.
				INFORM	APPE-4-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		04NOX2021-1 02/08/2021 16:44	410/NOXE	CRIT1	APPE-16-A	You did not provide AverageHourlyHeatInputRate, which is required for Operating Level 1.
				INFORM	APPE-4-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		04NOX2021-2 02/09/2016 15:28	400/NOXE	CRIT1	AETB-9-B	You reported an ExamDate that is after the date of the test for Dustin E. Banks.
					APPE-9-A	The test was conducted at the same time as another Appendix E test for MonitoringSystemID 400.
					APPE-10-A	You reported a test BeginDate, BeginHour, and BeginMinute that is not the same as the BeginDate, BeginHour, and BeginMinute of the first run in the Appendix E test.
					APPE-11-A	You reported an EndDate, EndHour, and EndMinute for the Appendix E test that is not the same as the EndDate, EndHour, and EndMinute of the last run in the test.
					PGVP-3-F	You have reported a vendor for Cylinder Identifier CC254003, but this vendor was not active at the time of this test.
						You have reported a vendor for Cylinder Identifier CC416465, but this vendor was not active at the time of this test.
						You have reported a vendor for Cylinder Identifier CC417166, but this vendor was not active at the time of this test.
						You have reported a vendor for Cylinder Identifier CC704813, but this vendor was not active at the time of this test.

Facility Name: Lincoln Combustion Turbine

QA/Cert Test Evaluation Report

Facility ID (ORISPL): 7277

October 12, 2022 04:22 PM

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
4	APPE	04NOX2021-2 02/09/2016 15:28	400/NOXE	CRIT2	PGVP-4-D	You reported an ExpirationDate for the cylinder that is more than eight years after the date of the test for Cylinder Identifier CC254003. Gas cylinders expire in less than eight years.
						You reported an ExpirationDate for the cylinder that is more than eight years after the date of the test for Cylinder Identifier CC416465. Gas cylinders expire in less than eight years.
						You reported an ExpirationDate for the cylinder that is more than eight years after the date of the test for Cylinder Identifier CC417166. Gas cylinders expire in less than eight years.
						You reported an ExpirationDate for the cylinder that is more than eight years after the date of the test for Cylinder Identifier CC704813. Gas cylinders expire in less than eight years.
				INFORM	APPE-4-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.