



ECMPS Client Tool

Version 1.* 2022 Q2

Emissions Evaluation Report

June 30, 2022 04:03 PM

Facility Name: Hayden

Facility Details

Facility ID (ORISPL): 525
Monitoring Plan Location IDs: H1
State: CO
County: Routt County
Year/Quarter: 2021 Q4
Total Hours: 2208

Evaluation Results

General Errors

Severity	Check Code / Result	Result Message
INFORM	HOURGEN-13-B	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.

Test Data Errors

Unit/Stack/ Pipe	Test Type	Test Date/Hour	Sys / Comp ID	Sys / Comp Type / Scale	Severity	Check Code	Result Message
H1	INTCHK	12/15/2021 06:16	125	FLOW/	CRIT1	EMTEST-6-B	You reported the value INC, which is not in the list of valid values for this test type, in the field TestResultCode for this test.

QA Status Errors

Unit/Stack/ Pipe	Category Description	Severity	Check Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
H1	Daily Interference Check Status Evaluation	CRIT1	OOC-Expired	The prior daily interference check for Component ID 125 completed on 12/07/2021 expired.	12/08/2021 08	12/09/2021 05	22
			OOC-No Prior Test	You did not report a prior daily interference check for Component ID 125 during the reporting period. Any daily interference check that may have been completed in a prior reporting period has expired.	12/06/2021 11	12/07/2021 05	19
			OOC-Test Aborted	The prior daily interference check for Component ID 125 completed on 12/10/2021 was aborted.	12/10/2021 06	12/11/2021 05	24
			OOC-Test Failed	The prior daily interference check for Component ID 125 completed on 12/12/2021 failed.	12/12/2021 06	12/13/2021 05	24
			OOC-Test Has Critical Errors	The prior daily interference check for Component ID 125 completed on 12/15/2021 has critical errors.	12/15/2021 06	12/16/2021 05	24

Facility Name: Hayden

Facility ID (ORISPL): 525

Emissions Evaluation Report

June 30, 2022 04:03 PM

Hourly Data Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
H1	INFORM	HOURMHV-16-G	You reported an MODCCode of 16 in the MHV record for SO2C, but the UnadjustedHourlyValue is equal to 2. According to Part 75.11(e)(3)(iii) any bias-adjusted hourly average SO2 concentration of less than 2.0 ppm recorded by the SO2 monitoring system shall be adjusted to a default value of 2.0 ppm, for reporting purposes.	12/06/2021 05	12/08/2021 09	53