



# ECMPS Client Tool

Version 1.\* 2022 Q2

## QA/Cert Test Evaluation Report

October 14, 2022 05:59 PM

**Facility Name:** IPL - Eagle Valley Generating Station

### Facility Details

Facility ID (ORISPL): 991  
State: IN  
County: Morgan County

### Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
GT2	7DAY	C21-1 02/09/2018 08:11	C21/NOX	CRIT1	<a href="#">SEVNDAY-3-A</a>	You did not provide TestReasonCode, which is required for this test.
				INFORM	<a href="#">SEVNDAY-5-C</a>	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		C22-1 02/09/2018 08:08	C22/O2	INFORM	<a href="#">SEVNDAY-4-A</a>	The TestResultCode indicates that the test was aborted. CalibrationInjection records for this test will not be evaluated. If the test was aborted for a reason not related to monitor performance, you should not report the test.
					<a href="#">SEVNDAY-5-C</a>	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.